



Product Service

# Attestation of Conformity

No. N8A 001309 0005 Rev. 04

**Holder of Attestation:** **Yixing JS Solar Co., Ltd.**  
No. 501, LvYuan Road  
Environment Science&Technology Mansion  
Environment Protection and  
Science&Technology Industry Park  
214200 Yixing  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**  
**Mono-Crystalline Silicon Photovoltaic Module**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704061801702-04

**Date,** 2023-01-17

( Zhulin Zhang )

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

# Attestation of Conformity

No. N8A 001309 0005 Rev. 04

**Model(s):**

JSxxxM, xxx=220 to 400 in step of 5,  
 JSxxxM, xxx=195 to 200 in step of 5,  
 JSxxxM, xxx=95 to 100 in step of 5,  
 JSxxxM144, xxx=365 to 450 in step of 5,  
 JSxxxM120, xxx=305 to 375 in step of 5,  
 JSxxxM144, xxx=525 to 550 in step of 5,  
 JSxxxM132, xxx=485 to 510 in step of 5,  
 JSxxxM120, xxx=435 to 460 in step of 5,  
 JSxxxM108, xxx=390 to 415 in step of 5,  
 JSxxxM132, xxx=640 to 670 in step of 5,  
 JSxxxM120, xxx=585 to 605 in step of 5,  
 JSxxxM108, xxx=525 to 545 in step of 5,  
 JSxxxM96, xxx=465 to 485 in step of 5,  
 JSxxxM84, xxx=405 to 425 in step of 5,  
 JSxxxM110, xxx=530 to 555 in step of 5,  
 JSxxxM100, xxx=480 to 505 in step of 5,  
 xxx is standing for rated output power at STC

**Parameters:**

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.

**Tested according to:**

EN IEC 61730-1:2018  
 EN IEC 61730-1:2018/AC:2018-06  
 EN IEC 61730-2:2018  
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



TUV®