

TÜV NORD (Hangzhou) Co., Ltd.

Room B409, Building 1, No. 9,
Jiuhuan Road, Shangcheng
District, Hangzhou City, Zhejiang
Province, 310019, P.R. China

Phone: +86 (0) 571 8538 6989
Fax: +86 (0) 571 8538 6986

hzpcert@tuv-nord.com
www.tuv-nord.com/cn

Evaluation Report No. 492013971.001

Outdoor Energy Storage System Qualification
according to IEC 62477-1:2012+AMD1:2016, EN 62477-1:2012+A1:2017, EN 62477-1:2012+A12:2021

Applicant: **Yixing JS Solar Co., Ltd.**
No.501, Lvyuan Road, Yixing, China

File No.: PVP07027/25E-001

Designed: by:  Digitally signed
by Owen Gu
Date: 2025.08.28
10:41:28 +08'00'

Reviewed: by:  Digitally signed
by Tong Huang
Date: 2025.08.28
12:20:53 +08'00'

All copyright and joint copyrights with respect to studies, assessments, test results, calculations, presentations, etc., drafted by TÜV NORD (Hangzhou) Co., Ltd. shall remain the property of TÜV NORD (Hangzhou) Co., Ltd. TÜV NORD (Hangzhou)'s contractual partner may use assessments, studies, test results, calculations, presentations, etc., drafted within the scope of the contract only for the purpose agreed in the contract or agreement. It is not permissible to pass on to third parties the reports, assessments, test results, calculations, presentations, etc., drawn up by TÜV NORD (Hangzhou) Co., Ltd. or to publish them in abridged form, unless the parties to the contract have concluded a written agreement on the passing on, presentation or publication of extracts from them.

Evaluation Report

File No.: PVP07027/25E-001

Report No.: 492013971.001

Applicant..... :	Yixing JS Solar Co., Ltd. No.501, Lvyuan Road, Yixing, China
Manufacturer :	Yixing JS Solar Co., Ltd. No.501, Lvyuan Road, Yixing, China
Factory..... :	Chuzhou Golen Power Co., Ltd. North Side Of Wen'an Road, Chahe Economic Development Zone, Lai'an County, Chuzhou City, Anhui Province, 239000, P.R. China
Order No. :	QT-PVP07027/25E
Date of Application [YYYY-MM-DD]..... :	2025-07-24
Product(s) :	Outdoor Energy Storage System
Model type(s) :	JSLES-241L120, JSLES-241L80, JSLES-241L60
Type of examination :	Parallel certification
Certification program: :	P31-VA-01 Rev. 03 / 02.25
Certification fundamental(s)..... :	IEC 62477-1:2012+AMD1:2016, EN 62477-1:2012+A1:2017 EN 62477-1:2012+A12:2021
Testing Period [YYYY-MM-DD] start/end..... :	N/A
Testing Laboratory..... :	N/A
Annex(es) :	Annex 1: Test report no. BL-DG2580040-201 (106 pages) Annex 2: Constructional Data Form (12 pages)

Test results listed in this test report refer exclusively to the mentioned test sample.

Partly copying is not permitted without explicit agreement of the owner.

The submitted test samples as described in the reports hereunder are in compliance with the requirements / are tested according to the requirements:

IEC 62477-1:2012+AMD1:2016, EN 62477-1:2012+A1:2017, EN 62477-1:2012+A12:2021 - "Safety requirements for power electronic converter systems and equipment - Part 1: General".

According to the inquiry of the applicant, based on certificate no. 44 799 25 406749 - 059 and evaluation report no. 492013677.001, issue parallel certificate.



中国认可
国际互认
检测
TESTING
CNAS L14701

TEST REPORT

Application number: PVP07027/25E-001

Applicant: Yixing JS Solar Co., Ltd.

Address: No.501, Lvyuan Road, Yixing, China

Equipment Type: Outdoor Energy Storage System

Model Name Under Test: JSLES-241L120

Model Name: JSLES-241L120, JSLES-241L80, JSLES-241L60

Brand Name: 

Ratings: See copy of marking label and model list.

Test Standard: IEC 62477-1:2012+AMD1:2016,
EN 62477-1:2012+A1:2017
EN 62477-1:2012+A12:2021☆

Sample Arrival Date: Nov. 27, 2024

Test Date: Nov. 27, 2024 to Mar. 03, 2025

Date of Issue: Aug. 26, 2025


ISSUED BY:

Dongguan BALUN Testing Technology Co., Ltd.

Tested by: Andy Duan



Checked by: Jin Huang



Approved by: Tao Zheng



Revision History

Version	Issue Date	Revisions Content
<u>Rev. 01</u>	<u>Aug. 26, 2025</u>	<u>Initial Issue</u>

-Note:

The only difference between the EUT (test samples in this report) and testing sample of report BL-DG2520035-201, which was issued by Dongguan BALUN Testing Technology Co., Ltd. On Mar. 06, 2025, as below:

1.Update information of applicant and manufacturer, model name, brand name, label and appearance.

And others hardware circuit and software were all the same. Based on the differences claimed by the customer, after evaluation, no clause needs to be retested. So other test data originate from the report BL-DG2520035-201.

Summary of testing:

All the tests results confirmed to the requirements of the standard.

Tests performed (name of test and test clause):

Requirement	Sub-Clause	Test
4.4.7.1, 4.4.7.5	5.2.2.1	Clearance and creepage distances test
4.4.3.3, 4.5.1.1, 4.6.3.3.2	5.2.2.2	Non-accessibility test
4.12.1	5.2.2.3	Ingress protection test (IP rating) ★
4.12.1	5.2.2.4.2.2	Steady force test, 30N
4.12.1	5.2.2.4.2.3	Steady force test, 250N
4.12.1	5.2.2.7	Handles and manual control securement test
4.4.7.10	5.2.3.2	Impulse voltage test
4.4.7.10	5.2.3.4	a.c. or d.c. voltage test
4.4.4.3.3	5.2.3.7	Touch current measurement
4.4.9	5.2.3.8	Capacitor discharge test
4.6.4	5.2.3.10	Temperature rise test
4.4.4.2.2	5.2.3.11	Protective equipotential bonding test
4.2	5.2.4	Abnormal operation tests
4.9	5.2.6.3.1	Dry heat test
4.9	5.2.6.3.2	Damp heat test
4.7.2.3.3	5.2.7	Hydrostatic pressure test (type test and routine test)

Testing location:

See report BL-DG2520035-201.

☒ The product fulfils the requirements of IEC 62477-1:2012+AMD1:2016, EN 62477-1:2012+A1:2017, EN 62477-1:2012+A12:2021☆.

Copy of marking plate:

JS SOLAR	
Outdoor Energy Storage System	
Model:JSLES-241L120	SN:JS20241122001
Battery Parameters	
Battery Designation	IFpP73/176/208/[[[(48S)5S]] M/-30+55/95
Rated Energy	241. 152kWh
Voltage Range	684~864Vdc
Rated Voltage	768Vdc
Rated Charge/Discharge Current	157A
AC Parameters	
Rated Output Power	120kW
Max.Apparent Output Power	132kVA
Rated Voltage	3/N/PE , 230/400Vac
Rated Frequency	50Hz
Rated Current	173A
Max.Output Current	191A
Power Factor	-0.9 lagging ~0.9 leading
Others	
Ingress Protection	IP54
Protective Class	Class I
Operating Temp. Range	-20℃~+50℃
Manufacture Date	2024.12.20
Yixing Js Solar Co.,Ltd.	

JS SOLAR	
Outdoor Energy Storage System	
Model:JSLES-241L80	SN:JS20241122001
Battery Parameters	
Battery Designation	IFpP73/176/208/[[[(48S)5S]] M/-30+55/95
Rated Energy	241. 152kWh
Voltage Range	684~864Vdc
Rated Voltage	768Vdc
Rated Charge/Discharge Current	157A
AC Parameters	
Rated Output Power	80kW
Max.Apparent Output Power	88kVA
Rated Voltage	3/N/PE , 230/400Vac
Rated Frequency	50Hz
Rated Current	115A
Max.Output Current	127A
Power Factor	-0.9 lagging ~0.9 leading
Others	
Ingress Protection	IP54
Protective Class	Class I
Operating Temp. Range	-20℃~+50℃
Manufacture Date	2024.12.20
Yixing Js Solar Co.,Ltd.	

JS SOLAR	
Outdoor Energy Storage System	
Model:JSLES-241L60	SN:JS20241122001
Battery Parameters	
Battery Designation	IFpP73/176/208/[[[(48S)5S]] M/-30+55/95
Rated Energy	241. 152kWh
Voltage Range	684~864Vdc
Rated Voltage	768Vdc
Rated Charge/Discharge Current	157A
AC Parameters	
Rated Output Power	60kW
Max.Apparent Output Power	66kVA
Rated Voltage	3/N/PE , 230/400Vac
Rated Frequency	50Hz
Rated Current	87A
Max.Output Current	95A
Power Factor	-0.9 lagging ~0.9 leading
Others	
Ingress Protection	IP54
Protective Class	Class I
Operating Temp. Range	-20℃~+50℃
Manufacture Date	2024.12.20
Yixing Js Solar Co.,Ltd.	

Test item particulars..... :	
Classification of installation and use..... : Class I, outdoor use	
Supply Connection..... : Permanent connection	
Possible test case verdicts:	
- test case does not apply to the test object..... : N/A	
- test object does meet the requirement..... : P (Pass)	
- test object does not meet the requirement..... : F (Fail)	
General remarks:	
"(See Enclosure #)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report. The tests results presented in this report relate only to the object tested. This report shall not be reproduced except in full without the written approval of the testing laboratory. List of test equipment must be kept on file and available for review. Additional test data and/or information provided in the attachments to this report. Throughout this report a ☐ comma / ☒ point is used as the decimal separator. Determination of the test results includes consideration of measurement uncertainty from the test equipment and methods.	
Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60068-2-1:	
The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided :	☐ Yes ☒ Not applicable
When differences exist; they shall be identified in the General product information section.	
None	
Name and address of manufacturer (ies)	Yixing JS Solar Co., Ltd. No.501, Lv Yuan Road, Yixing, China
Name and address of factory (ies)	Chuzhou Golen Power Co., Ltd. North Side Of Wen'an Road, Chahe Economic Development Zone, Lai 'an County, Chuzhou City, Anhui Province, 239000, P.R. China

General product information:

The unit under test is Outdoor Energy Storage System. Which mainly combine by DC/AC power converter unit (PCS), Liquid cooling unit, battery pack, battery control unit, fire protection unit, power distribution box.

During inverter, which convert the variable DC power generated from the Batteries to the stable utility AC power which can be fed into the commercial electrical grid or off-grid load. When charging, the grid converts the alternating current into direct current into the battery through the Power Conversion Unit.

For PCS, there are two relays in series as interface protection for AC side, and each one contactor in positive and negative for DC side. The certificate number of PCS is TUV NORD 4479925406749-041. For Battery system, there are each one contactor in positive and negative terminal, also with a 250A DC switch as protection device. The certificate number of Battery system is TUV NORD 4479925406749-057.

PCS:

Hardware Version: LEG-135K-TL-P-HD-E021-001

Software Version: GL-S03-ZL135-001-1.0-241210

Battery system:

Firmware version of BCU: V1.4

Firmware version of BMU: V1.4


Software Version of BCU: 13.81.5.8.15

Model Difference:

All models use the same software program and hardware, and the main control circuit, drive circuit and power topology, and limit the power through software.

Unless otherwise specified, all tests are performed on the model JSLES-241L120 for JSLES-241L80, JSLES-241L60 expect cl 4. Since they use the same software program and hardware, and the main control circuit, drive circuit and power topology, and limit the power through software.

Block diagram:



Model list:

Outdoor Energy Storage System			
Model or Type designation	JSLES-241L120	JSLES-241L80	JSLES-241L60
AC parameters:			
Rated Voltage [Va.c.]	230/400Vac, 3L/N/PE		
Rated Frequency [Hz]	50		
Rated Power [kW]	120	80	60
Max. Apparent Power [kVA]	132	88	66
Rated Current [Aa.c.]	173	115	87
Max. Current [Aa.c.]	191	127	95
Power Factor cosφ [λ]	-0.9 lagging ~0.9 leading		
Battery parameters:			
Battery capacity [Ah]	314		
Battery type	IFpP73/176/208/[((48S)5S)]M/-30+55/95		
Rated energy [kWh]	241.152		
Rated voltage [Vd.c.]	768		
Voltage range [Vd.c.]	684~864		
Rated current [Ad.c.]	157		
Others:			
Protective Class	Class I		
Inverter Topology	Non-isolated		
Operation Temperature Range [°C]	-20 to 50 (>45 derating)		
Ingress Protection	PCS: IP20 Battery room: IP20 High Voltage box: IP54 Combiner box: IP54		
Weight [kg]	2400		
Dimension (W*D*H) [mm]	1000*1330*2350		
Overvoltage-Category	DC(BAT) II, AC(Main) III		

Additional test item particulars:	
Equipment mobility:	☐ movable ☐ hand-held ☐ stationary ☒ fixed ☐ transportable ☐ for building-in
Connection to the mains:	☐ pluggable equipment ☐ direct plug-in ☒ permanent connection ☐ for building-in
Environmental category:	☒ outdoor ☐ indoor unconditional ☐ indoor conditional
Over voltage category Mains:	☐ OVC I ☐ OVC II ☒ OVC III ☐ OVC IV
Over voltage category DC:	☐ OVC I ☒ OVC II ☐ OVC III ☐ OVC IV
Mains supply tolerance (%):	According to the specified supply range
Tested for power systems:	TN
IT testing, phase-phase voltage (V):	N/A
Class of equipment:	☒ Class I ☐ Class II ☐ Class III ☐ Not classified
Mass of Max. equipment (kg):	Refer to model list
Pollution degree:	External PD3, Internal PD2
IP protection class :	Refer to model list

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
4	PROTECTION AGAINST HAZARDS		P
4.1	General		P
4.2	Fault and abnormal conditions	See Table 4.2 to 4.3	P
	Components in 4.2 also include insulation systems, ports, etc (IEC 62477-1:2012/AMD1:2016)		P
4.3	Short-circuit and overcurrent protection	See Table 4.2 to 4.3	P
4.3.1	General		P
4.3.2	Specification of prospective short-circuit current		P
4.3.2.1	General	See below	P
	The interrupting capability of the overcurrent protective device shall be equal or greater than the prospective short circuit current of the mains supply.	Considered.	P
	For pluggable equipment type A, either the PECS shall be designed so that the building installation provides short circuit backup protection, or additional short circuit backup protection shall be provided as part of the equipment.	Permanently connected equipment	N/A
	For permanently connected equipment or pluggable equipment type B, it is permitted for short circuit backup protection to be in the building installation.	Considered.	P
4.3.2.2	In case the PECS manufacturer selects the conditional short-circuit current (I_{cc}) rating according to 4.3.1, the following specified: (IEC 62477-1:2012/AMD1:2016)		P
	Specification of the rated conditional short-circuit current (I_{cc}) on input ports (IEC 62477-1:2012/AMD1:2016)		P
	- conditional short-circuit current (I_{cc}), (IEC 62477-1:2012/AMD1:2016)		P
	- characteristics of the short-circuit protective device, and (IEC 62477-1:2012/AMD1:2016)		P
	- minimum required prospective short-circuit current ($I_{cp,mr}$) (IEC 62477-1:2012/AMD1:2016)		P
	If it is shown by analysis that the result of one test is representative of the worst case, less severe combinations need not be tested. (IEC 62477-1:2012/AMD1:2016)		P
4.3.2.3	Output short circuit current ability	Considered.	P
	The output short circuit current ratings apply to a.c. and d.c. power output ports and to	Considered.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	other ports for which overcurrent protection is necessary. For all output ports, short circuit evaluation to determine the minimum and maximum output short circuit current shall be performed according to 5.2.4.4 and the output short circuit current available from the PECS shall be specified as in 5.2.4.4 and 6.2. Internal electronic output short circuit protection is considered acceptable as an output short circuit protection device of the PECS, when compliance is shown by test in 5.2.4.4.		
4.3.2.4	Combined input and output ports	Considered.	P
	For ports which are both input and output ports the applicable requirements of both 4.3.2.1 and 4.3.2.3 apply.	Fulfil requirements	P
4.3.3	Short-circuit coordination (backup protection)	Considered.	P
	Protective devices provided or specified shall have adequate breaking capability to interrupt the maximum prospective short circuit current specified for the port to which they are connected. If internal protection of the PECS is not rated for the prospective short circuit current, the installation instructions shall specify an upstream protective device, rated for this prospective short circuit current of that port, which shall be used to provide backup protection. Analysis shall ensure the protection coordination between the external and internal protective device.	The protection device has adequate breaking capacity.	P
	Compliance shall be checked by inspection and by the tests of 5.2.4.4 and 5.2.4.5.	Fulfil requirements	P
4.3.4	Protection by several devices	Considered.	P
	Where protective devices that require manual replacement or resetting are used in more than one pole of a supply to a given load, those devices shall be located together. It is permitted to combine two or more protective devices in one component. Compliance shall be checked by inspection.	Fulfil requirements	P
4.3.5	In case the PECS manufacturer selects the short time withstand current (I_{cw}) rating according to 4.3.1, the following specified: (IEC 62477-1:2012/AMD1:2016)		P
	Input ports short time withstand current, I_{cw} (IEC 62477-1:2012/AMD1:2016)		P
	- rated short time withstand current (I_{cw}), (IEC		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	62477-1:2012/AMD1:2016)		
	- associated duration, and (IEC 62477-1:2012/AMD1:2016)		P
	- rated peak withstand current (I_{pk}). (IEC 62477-1:2012/AMD1:2016)		P
	If it is shown by analysis that the result of one test is representative of the worst case, less severe combinations need not be tested. (IEC 62477-1:2012/AMD1:2016)		P
4.4	Protection against electric shock		P
4.4.1	General		P
4.4.2	Decisive voltage classification		P
4.4.2.1	General	Considered	P
4.4.2.2	Determination of decisive voltage class		P
4.4.2.2.1	General	See below	P
	For protection against the ventricular fibrillation body reaction, DVC can be selected from Table 2.	Water wet conditions DVC A	P
4.4.2.2.2	Selection tables for contact area and skin humidity condition		P
	In order to protect against ventricular fibrillation, the appropriate conditions from Table 3 and Table 4 shall be selected.	Considered	P
4.4.2.2.3	Limits of the working voltage for the DVC	Considered	P
4.4.2.3	Requirements for protection against electric shock		P
4.4.3	Provision for basic protection		P
4.4.3.1	General	Considered	P
4.4.3.2	Protection by means of insulation of live parts	Considered	P
	Live parts shall be completely surrounded with insulation if their working voltage is greater than DVC As or if they do not have protective separation from adjacent circuits of DVC C.	Live parts protective separation from adjacent circuits of DVC C.	P
	Basic insulation may be provided by solid insulation or air clearance.	Both solid insulation and air clearance	P
	The insulation shall be rated according to the impulse voltage, temporary overvoltage or working voltage (see 4.4.7.2.1), whichever gives the most severe requirement. It shall not be possible to remove the insulation	The insulation can't be removed without use of tools or key.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	without the use of a tool or key.		
4.4.3.3	Protection by means of enclosures or barriers	Considered	P
	Live parts with voltage higher than DVC As shall be: - arranged in enclosures or located behind enclosures or barriers, which meet at least the requirements of the Protective Type IPXXB according to Clause 7 of IEC 60529:1989; - located at the top surfaces of enclosures or barriers which are accessible when the equipment is energized shall meet at least the requirements of the protective type IP3X with regard to vertical access only.		P
	For moveable equipment with no defined top and bottom this requirement of protective Type IP3X applies to all sides.	Fixed equipment	N/A
	If the PECS is installed in a restricted access area, IPXXB instead of IP3X applies.		N/A
	Product committees using this document as reference document might consider less requirement for equipment having openings in the top of an enclosure with a height exceeding 1.8 m.		P
	Compliance is shown by test of 5.2.2.2.		P
	It shall only be possible to open enclosures or remove barriers: • with the use of a tool or key; or • after de-energization of these live parts.	Considered	P
	Where the enclosure is required to be opened and the PECS energized during installation or maintenance: a) accessible live parts of voltage higher than DVC As shall be protected by at least IPXXA; b) live parts of voltage higher than DVC As that are likely to be touched when making adjustments shall be protected by at least IPXXB; c) it shall be ensured that persons are aware that live parts with voltage higher than DVC As are accessible.	The enclosure is no required to be opened and the PECS energized during installation or maintenance	N/A
4.4.3.4	Protection by means of limitation of touch current and charge		P
	The limitation of touch current and discharge energy shall not exceed:		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	- a value of 3.5 mA a.c. or 10 mA d.c. for the limitation of touch current; and - a value of 50 μC for the limitation of discharge energy.		
4.4.3.5	Protection by means of limited voltages	Considered	P
	The voltage between simultaneously accessible parts shall not be greater than DVC As as determined in 4.4.2.2.		P
4.4.4	Provision for fault protection		P
4.4.4.1	General		P
	Fault protection shall be provided by one or more of the following measures: • Protective equipotential bonding in 4.4.4.2 in combinations with the PE conductor in 4.4.4.3; • Automatic disconnection of supply in 4.4.4.4; • Supplementary insulation in 4.4.4.5; • Simple separation between circuits in 4.4.4.6; • Electrically protective screening in 4.4.4.7. Fault protection shall be independent and additional to those for basic protection.	Considered	P
4.4.4.2	Protective equipotential bonding		P
4.4.4.2.1	General		P
	Protective equipotential bonding shall be provided between accessible conductive parts of the equipment and the means of connection for the PC conductor, except: a) accessible conductive parts that are protected by one of the measures in 4.4.6.4; or b) when accessible conductive parts are separated from live parts using double or reinforced insulation.	Considered	P
	Electrical contact to the means of connection of the PE conductor shall be achieved by one or more of the following means: • through direct metallic contact; • through other accessible conductive parts or other metallic components which are not removed when the PECS is used as intended; • through a dedicated protective	Through direct metallic contact	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	equipotential bonding conductor.		
4.4.4.2.2	Rating of protective equipotential bonding		P
	Protective equipotential bonding shall either be: a) sized in accordance with the requirements for the PE conductor in 4.4.4.3 and the means of connection for the PE conductor in 4.4.4.3.2 to ensure no voltage drop exceeding the values from 4.4.2.2.3 during a fault; or b) sized • to withstand the highest stresses that can occur to the PECS item(s) concerned when they are subjected to a fault connecting to accessible conductive parts; and • to remain effective for as long as a fault to the accessible conductive parts persists or until an upstream protective device removes power from the part; and • to ensure no voltage drop exceeding the values from 4.4.2.2.3 during normal operation and during a fault. Compliance shall be checked with the type tests in 5.2.3.11	The enclosure of the individual components is in direct contact with the frame during installation and cross-sectional area the external protective earthing conductor as required in the installation instruction is min.25 mm ² (S/2)	P
4.4.4.3	PE conductor		P
4.4.4.3.1	General		P
	A PE conductor shall be connected at all times when power is supplied to the PECS, unless the PECS complies with the requirements of protective class II (see 4.4.6.3) or protective class III. Unless local wiring regulations state otherwise, the PE conductor cross-sectional area shall be determined from Table 7 or by calculation according to 543.1 of IEC 60364-5-54:2011.	Considered	P
	If the PE conductor is routed through a plug and socket, or similar means of disconnection, it shall not be possible to disconnect it unless power is simultaneously removed from the part to be protected.	Not this means	N/A
	The cross-sectional area of every PE conductor that does not form part of the supply cable or cable enclosure shall, in any case, be not less than: • 2.5 mm² if mechanical protection is provided; or • 4 mm² if mechanical protection is not provided.	25 mm ²	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Provisions within cord-connected equipment shall be made so that the PE conductor in the cord shall, in the case of failure of the strain-relief mechanism, be the last conductor to be interrupted. For special system topologies, the PECS designer shall verify the PE conductor cross-section required.	Considered	P
4.4.4.3.2	Means of connection for the PE conductor		P
	PECS shall have a means of connection for the PE conductor, located near the terminals for the respective live conductors. The means of connection shall be corrosion-resistant and shall be suitable for the connection of conductors according to Table 7 and of cables in accordance with the wiring rules applicable at the installation. The means of connection for the PE conductor shall not be used as a part of the mechanical assembly of the equipment or for other connections. Connection and bonding points shall be designed so that their current-carrying capacity is not impaired by mechanical, chemical, or electrochemical influences. Where enclosures and/or conductors of aluminium or aluminium alloys are used, particular attention should be given to the problems of electrolytic corrosion. Compliance shall be checked by inspection.		P
4.4.4.3.3	Touch current in case of failure of PE conductor		P
	For all other PECS, one or more of the following measures shall be applied, unless the touch current can be shown to be less than the limits specified in 4.4.3.4: a) Use of a fixed connection and - a cross-section of the PE conductor of at least 10 mm² Cu or 16 mm² Al; or - automatic disconnection of the supply in case of discontinuity of the PE conductor; or - provision of an additional terminal for a second PE conductor of the same cross-sectional area as the original PE conductor; or b) Use of a pluggable type B connection with	A cross-section of the PE conductor of at least 25 mm ² yellow-green cables shall be used.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	a minimum PE conductor cross-section of 2.5 mm ² as part of a multi-conductor power cable. Adequate strain relief shall be provided.		
	Compliance is checked by inspection and by test of 5.2.3.7.		P
4.4.4.4	Automatic disconnection of supply	Not this means	N/A
	For automatic disconnection of supply: • a protective equipotential bonding system shall be provided; and • a protective device operated by the fault current shall disconnect one or more of the line conductors supplying the equipment, system or installation, in case of a failure of basic insulation. The protective device shall interrupt the fault current within a time as specified in Figure 1, Figure 2 or Figure 3 in 4.4.2.2.3.	No such device	N/A
4.4.4.5	Supplementary insulation	Considered	P
4.4.4.6	Simple separation between circuits		P
	If any component is connected between the separated circuits, that component shall withstand the electric stresses specified for the insulation which it bridges. If any component is connected between a circuit and a circuit connected to earth, its impedance shall limit the current flow through the component to the steady-state touch current values indicated in 4.4.3.4.	Considered	P
4.4.4.7	Electrically protective screening		P
	Electrically protective screening interposed between hazardous live parts of a PECS, shall consist of a conductive screen connected to the protective equipotential bonding of the PECS whereby the screen is separated from live parts by at least simple separation. The protective screen and the connection to the protective equipotential bonding system of the PECS and that interconnection shall comply with the requirements of 4.4.4.2.	Considered	P
4.4.5	Enhanced protection		P
4.4.5.1	General		P
	Enhanced protection shall provide both basic and fault protection and can be achieved by means of:	Considered	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	- Reinforced insulation in 4.4.5.2; - Protective separation between circuits in 4.4.5.3; - Protection by means of in 4.4.5.4.		
4.4.5.2	Reinforced insulation		P
	Reinforced insulation shall be so designed as to be able to withstand electric, thermal, mechanical and environmental stresses with the same reliability of protection as provided by double insulation. (basic insulation and supplementary insulation, see 4.4.3.2 and 4.4.4.5)	Considered	P
4.4.5.3	Protective separation between circuits		P
	Protective separation between a circuit and other circuits shall be achieved by one of the following means: - double insulation (basic insulation and supplementary insulation in 4.4.3.2 and 4.4.4.5); - reinforced insulation in 4.4.5.2; - electrically protective screening in 4.4.4.7; - a combination of these provisions.	Reinforced insulation	P
	If conductors of the separated circuit are contained together with conductors of other circuits in a multi-conductor cable or in another grouping of conductors, they shall be insulated, individually or collectively, for the highest voltage present, so that double insulation is achieved. If any component is connected between the separated circuits, that component shall comply with the requirements for protective impedance devices (see 4.4.5.4)	Considered	P
4.4.5.4	Protection by means of protective impedance		N/A
	Protective impedance shall be arranged so that under both normal and single fault conditions the current and discharge energy available shall be limited according to 4.4.3.4.		N/A
	The protective impedances shall be designed and tested to withstand the impulse voltages and temporary overvoltages for the circuits to which they are connected. See 5.2.3.2 and 5.2.3.4 for tests.		N/A
	Compliance with the requirement for the limitation of touch current is checked by test		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	of 5.2.3.6.		
	Compliance with the requirement for the discharge energy shall be checked by performing calculations and/or measurements to determine the voltage and capacitance. NOTE A protective impedance designed according to this subclause is not considered to be a galvanic connection.		N/A
4.4.6	Protective measures		P
4.4.6.1	General		P
4.4.6.2	Protective measures for protective class I equipment		P
	Protective class I equipment shall meet the requirements for: • basic protection in 4.4.3; and • fault protection in 4.4.4.2 and 4.4.4.3 with respect to equipotential bonding and PE conductor.	Considered	P
4.4.6.3	Protective measures for protective class II equipment	Class I equipment	N/A
	Protective class II equipment shall meet the requirements for enhanced protection according to 4.4.5 and the enclosure shall meet the requirement for basic protection in 4.4.3 with respect to accessibility to hazardous live parts. Protective class II equipment shall not have means of connection for the PE conductor. This does not apply if a PE conductor is passed through the equipment to equipment series-connected beyond it. In the latter case the PE conductor and its means for connection shall be separated from: • accessible surface of the equipment; and • circuits which employ protective separation with at least simple separation according to the requirement in 4.4.4.6. The simple separation shall be designed according to the rated voltage of the series-connected equipment.	Class I equipment	N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Equipment of protective class II may have provision for the connection of an earthing conductor for functional reasons or for the damping of overvoltages. In this case, the functional earthing conductor shall be separated from: • accessible surface of the equipment; and • circuits which employ protective separation according to 4.4.5.3 with at least protective separation according to the requirement in 4.4.5.3. Equipment of protective class II shall be marked according to 6.3.7.3.3. Compliance is checked by inspection.		
4.4.6.4	Protective measures for protective class III equipment		N/A
4.4.6.4.1	General	Class I equipment	N/A
	Protective measures shall be achieved by protective separation by one of the following means: • basic insulation and supplementary insulation (double insulation) according to 4.4.3.2 and 4.4.4.5; • reinforced insulation according to 4.4.5.2; • electrically protective screening and simple separation according to 4.4.4.7; or • a combination of these provisions; used in combination with one of the following means: • protective impedance according to 4.4.5.4 comprising limitation of discharge energy and of current; or • limitation of voltage according to 4.4.3.5.	Class I equipment	N/A
	The protective separation shall be fully and effectively maintained under all conditions of intended use of the PECS.	Class I equipment	N/A
4.4.6.4.2	Connection to PELV and SELV circuits		N/A
	If a port is intended for connection of an external PELV or SELV circuit with a higher voltage than DVC As: • measures to limit the voltage to that of DVC As shall be taken (see Annex A); or • basic protection shall be provided. For connectors containing pins with very		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	small contact area ($< 1 \text{ mm}^2$), the next higher voltage level for DVC As, of Table 5, is permitted. Example: if DVC A1 is DVC As, then DVC A2 is permitted at pins of signal connectors. The connection of external PELV or SELV circuits to an internal circuit is permitted with the following consideration: • without measures: only if the DVC of the PELV and SELV voltage are lower than or equal to the DVC selected from Table 5 for the internal circuit under consideration; and • with measures: if the DVC of the PELV and SELV voltage are higher than the DVC selected from Table 5 for the internal circuit under consideration. The possibility of an addition of the voltages of the circuits under consideration to a higher level under fault conditions shall be considered. For marking, see 6.3.7.1. Consideration needs to be given to factors such as whether the circuits involved are earthed or not, what the voltages involved are, whether or not direct contact with live parts is possible, single faults in either equipment or the interconnections, etc.		
4.4.7	Insulation		P
4.4.7.1	General		P
4.4.7.1.1	Influencing factors		P
	This subclause gives minimum requirements for insulation, based on the principles of IEC 60664.		P
	Insulation shall be selected after consideration of the following influences: - pollution degree; - overvoltage category; - supply system earthing; - impulse withstand voltage, temporary overvoltage and working voltage; - location of insulation; - type of insulation.	Considered.	P
	Verification of insulation shall be made according to 5.2.2.1, 5.2.3.2, 5.2.3.4 and 5.2.3.5.	See table 4.4.7.4 to 4.4.7.5	P
4.4.7.1.2	Pollution degree		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Insulation, especially when provided by clearances and creepage distances, is affected by pollution which occurs during the expected lifetime of the PECS. The micro-environmental conditions for insulation shall be applied according to Table 8.	Pollution degree 2 internally	P
	The pollution degree shall be determined according to the environmental condition for which the product is specified. See Table 18 for selection of pollution degree according to environmental classification of the installation.	Considered.	P
	The insulation may be determined according to pollution degree 2 if one of the following applies: a) instructions are provided with the PECS indicating that it shall be installed in a pollution degree 2 environment; or b) the specific installation application of the PECS is known to be a pollution degree 2 environment; or c) the PECS enclosure or coatings applied within the PECS according to 4.4.7.8.4.2 or 4.4.7.8.6 provide adequate protection against what is expected in pollution degree 3 and 4 (conductive pollution and condensation).		N/A
	The PECS manufacturer shall state in the documentation the pollution degree for which the PECS has been designed.	The PECS manufacturer state in the documentation the pollution degree for which the PECS has been designed.	P
	If operation in a pollution degree 4 environment is required, protection against conductive pollution shall be provided by means of a suitable enclosure.	No this required	N/A
4.4.7.1.3	Overvoltage category (OVC)		P
	The measures for reduction of the impulse voltage shall ensure that the temporary overvoltages that could occur are sufficiently limited so that their peak value does not exceed the relevant rated impulse voltage of Table 9 and shall meet the requirement of 4.4.7.2.2, 4.4.7.2.3 and 4.4.7.3 as applicable.	Considered.	P
	Four categories are considered. • Equipment of overvoltage category IV (OVC IV) is for use at the origin of the installation. • Equipment of overvoltage category III (OVC III) is equipment in fixed installations and for	For DC circuits: Overvoltage Category II For AC circuits: Overvoltage Category III	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	cases where the reliability and the availability of the equipment are subject to special requirements. • Equipment of overvoltage category II (OVC II) is energy-consuming equipment to be supplied from the fixed installation. • Equipment of overvoltage category I (OVC I) is equipment for connection to circuits in which measures are taken to limit transient overvoltages to an appropriately low level.		
4.4.7.1.4	Supply earthing systems		P
	The following three basic types of system earthing are described in IEC 60364-1. • TN system: has one point directly earthed, the accessible conductive parts of the installation being connected to that point by protective conductors. Three types of TN system, TN-C, TN-S and TN-C-S, are defined according to the arrangement of the neutral and protective conductors. • TT system: has one point directly earthed, the accessible conductive parts of the installation being connected to earth electrodes electrically independent of the earth electrodes of the power system. • IT system: has all live parts isolated from earth or one point connected to earth through an impedance, the accessible conductive parts of the installation being earthed independently or collectively to the system earthing.	TN system considered.	P
4.4.7.1.5	Determination of impulse withstand voltage and temporary overvoltage		P
	Table 9 uses the system voltage (see 4.4.7.1.6) and overvoltage category of the circuit under consideration to determine the impulse withstand voltage. The system voltage is also used to determine the temporary overvoltage. A PECS having more than one input or output shall be evaluated according to the input or output which gives the most severe requirements.	Considered.	P
4.4.7.1.6	Determination of the system voltage		P
4.4.7.1.6.1	For mains supply		P
4.4.7.1.6.2	For non-main supply		P
	For PCS supplied by non-mains a.c. or d.c., the system voltage is the r.m.s. value of the	DC battery supply	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	supply voltage between phases.		
4.4.7.1.7	Components bridging insulation		P
	Components bridging insulation shall comply with the requirements of the level of insulation (e.g. basic, reinforced, double) they are bridging.	Certified components used	P
4.4.7.2	Insulation to the surroundings		P
4.4.7.2.1	General		P
4.4.7.2.2	Circuits connected to mains supply		P
	Insulation between the surroundings and circuits which are connected directly to the mains supply shall be designed according to the impulse withstand voltage, temporary overvoltage, or working voltage, whichever gives the most severe requirement.	Considered.	P
4.4.7.2.3	Circuits connected to Non-mains supply		P
	Insulation between the surroundings and circuits supplied from a non-mains supply shall be designed according to: • the impulse withstand voltage determined from Table 9 using the system voltage; • the working voltage; • the temporary overvoltage if known to exist due to the nature of the supply; whichever gives the more severe requirement.		P
	Temporary overvoltage on a non-mains supply shall be determined as follows: • Without detailed knowledge of the temporary overvoltage, it shall be according to Table 9. • If the temporary overvoltage is known this value shall be used.		N/A
	By the determination of temporary overvoltages on non-mains supply, following situations should be considered: • loss of the neutral in a non-mains low-voltage system; • accidental earthing of a non-mains low voltage IT system; and • short circuit in the non-mains low voltage installation.		N/A
4.4.7.2.4	Insulation between circuits		P
	Insulation between two circuits shall be designed according to the circuit having the	Considered.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	more severe requirement. For the design of simple and protective separation between circuits the insulation shall be designed according to: • the circuit having the more severe requirement; or • the working voltage between the circuits; whichever gives the most severe requirement.		
4.4.7.3	Functional insulation		P
	If the failure of functional insulation does not produce a hazard (electrical, thermal, fire), no specific requirements apply for the dimensioning of functional insulation. In other cases the following requirements apply. Testing is not required, except where the circuit analysis required by 4.2 shows that failure of the insulation could result in a hazard. For parts or circuits that are significantly affected by external transients, functional insulation shall be designed according to the impulse withstand voltage of overvoltage category II, except that overvoltage category III shall be used when the PECS is connected at the origin of the installation. Where measures are provided that reduce transient overvoltages within the circuit from category III to values of category II, or values of category II to values of category I, functional insulation may be designed for the reduced values. Where the circuit characteristics can be shown by testing (see 5.2.3.2) to reduce impulse voltages, functional insulation may be designed for the highest impulse voltage occurring in the circuit during the tests. For parts or circuits that are not significantly affected by external transients, functional insulation shall be designed according to the working voltage across the insulation.	Considered.	P
4.4.7.4	Clearance distance		P
4.4.7.4.1	Determination	See Table 4.4.7.4	P
	Clearances for functional, basic and supplementary insulation shall be dimensioned according to Table 10 (see Annex D for examples of the evaluation of clearance distances). Interpolation is permitted, when clearance is determined from temporary overvoltage or working	Considered.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	voltage. Clearances for reinforced insulation shall be dimensioned to withstand an impulse voltage one step higher than the impulse withstand voltage, or 1.6 times the peak temporary overvoltage or peak working voltage, required for basic insulation. Clearance distances for use in altitudes between 2 000 m and 20 000 m shall be calculated using a correction factor according to Table A.2 of IEC 60664-1:2007, which is reproduced as Table E.1. A correction factor selected from Table F.2 is also used for determination of clearance distances for approximately homogenous fields when frequencies are greater than 30 kHz, as given in Annex F.		
	Compliance shall be checked by visual inspection (see 5.2.2.1) or by performing the impulse voltage test of 5.2.3.2 and the a.c. or d.c. voltage test of 5.2.3.4.	Fulfil requirements	P
4.4.7.4.2	Electric field homogeneity		P
	The dimensions in Table 10 correspond to the requirements of an inhomogeneous electric field distribution across the clearance, which are the conditions normally experienced in practice. If a homogeneous electric field distribution is known to exist, the clearance distance for basic or supplementary insulation may be reduced to not less than that required by Table F.2 (Case B) of IEC 60664-1:2007. In this case, however, the impulse voltage test of 5.2.3.2 shall be performed across the considered clearance. If the withstand against steady state voltages, recurring peak or temporary overvoltages according to Table 10 is decisive for the dimensioning of clearance and if these clearances are smaller than the values of Table 10 then an a.c. or d.c. voltage test according to 5.2.3.4 is required. Clearance distances for reinforced insulation shall not be reduced for homogeneous fields.		P
4.4.7.4.3	Clearance to conductive enclosures	Considered	P
	The clearance between any non-insulated live part and the walls of a metal enclosure shall be in accordance with 4.4.7.4.1 during and following the deflection tests of 5.2.2.4.2.	See table 4.4.7.4 to 4.4.7.5	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Compliance is checked by inspection and by test of 5.2.2.4.2.	See table 4.4.7.4 to 4.4.7.5	P
	If the design clearance distance is at least 12.7 mm and the clearance distance required by 4.4.7.4.1 does not exceed 8 mm, the deflection tests may be omitted.		N/A
4.4.7.5	Creepage distance		P
4.4.7.5.1	Insulating material groups	Considered	P
	Creepage distance requirements for PWBs exposed to pollution degree 3 environmental conditions shall be determined based on Table 11 pollution degree 3 under “Other insulators”.		P
	For inorganic insulating materials, for example glass or ceramic, which do not track, the creepage distance may equal the associated clearance distance, as determined from Table 10.		P
4.4.7.5.2	Determination	See Table 4.4.7.5	P
	Creepage distances for functional, basic and supplementary insulation shall be dimensioned according to Table 11. Interpolation is permitted. Creepage distances for reinforced insulation shall be twice the distances required for basic insulation.		P
	When the creepage distance requirement determined from Table 11 is less than the clearance distance required by 4.4.7.4.1 or the clearance distance determined by impulse testing (see 5.2.3.2), then the creepage distance shall be increased to the clearance distance.		P
	Compliance of creepage distances shall be checked by measurement or inspection (see 5.2.2.1) (see Annex D for examples of the evaluation of creepage distances).		P
4.4.7.6	Coating	No such coating used.	N/A
	A coating may be used to provide insulation, to protect a surface against pollution, and to allow a reduction in creepage and clearance distances (see 4.4.7.8.4.2 and 4.4.7.8.6)		N/A
4.4.7.7	PWB spacings for functional insulation	Considered	P
	Spacings for functional insulation shall comply with the requirement of 4.4.7.4 and 4.4.7.5.	See Table 4.4.7.5	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Decreased spacings on PWB are permitted when all the following are satisfied: • the PWB has flammability rating of V-0 (see IEC 60695-11-10); • the PWB base material has a minimum CTI of 100; • the equipment complies with the PWB short circuit test (see 5.2.4.7). Decreased spacings for components assembled on PWB are permitted when used in: • pollution degree 1 or 2 environment; and • not more than overvoltage category I. In this case the manufacture specification may be used. Compliance is checked by inspection and by test of 5.2.4.7 if applicable.		P
4.4.7.8	Solid insulation		P
4.4.7.8.1	General	See Table 4.4.7.5	P
	Materials selected for solid insulation shall be able to withstand the stresses occurring. These include mechanical, electrical, thermal, climatic and chemical stresses which are to be expected in normal use. Insulation materials shall also be resistant to ageing during the expected lifetime of the PECS. Tests shall be performed on components and sub-assemblies using solid insulation, in order to ensure that the insulation performance has not been compromised by the design or manufacturing process.		P
4.4.7.8.2	Material requirements	Considered	P
	The insulating material shall have a CTI of 100 or greater. The insulating material shall be suitable for the maximum temperature it attains as determined by the temperature rise test of 5.2.3.10. Consideration shall be given as to whether or not the insulating material additionally provides mechanical strength and whether or not the part can be subject to impact during use.	Fulfil requirements	P
	The insulating material in contact with live parts higher than DVC As shall comply with: • the glow-wire test described in 5.2.5.3 at a test temperature of 850 °C; or • the glow-wire test described in 5.2.5.3, at a lower test temperature, but not less than	There is no insulating material in contact with the live parts higher than DVC	N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	550 °C, depending on the classification of the use of the PECS, according to Table A.1 of IEC 60695-2-11:2011; or • the alternative hot wire ignition test of 5.2.5.4.		
	Thermoplastic insulating materials used in contact with live parts higher than DVC As or used as part of the enclosure shall comply with the ball pressure test as abnormal heat test according to IEC 60695-10-2.		N/A
	Where an insulating material is used in a PECS that incorporates switching contacts, and is within 12.7 mm of the contacts, it shall comply with the high current arcing ignition test of 5.2.5.2.	Without such material	N/A
	In case the manufacturer of the insulating material provides data to demonstrate compliance with the above requirements no further testing is required. No further evaluation is required when generic materials are used according to Table 12.	The manufacturer provides data to demonstrate compliance with the above requirements	P
	Compliance is checked by inspection and by test of 5.2.3.10 and 5.2.5.3 or 5.2.5.2.		N/A
4.4.7.8.3	Thin sheet or tape material		P
4.4.7.8.3.1	General		P
	4.4.7.8.3 applies to the use of thin sheet or tape materials in assemblies such as wound components and bus-bars. Insulation consisting of thin (less than 0.75 mm) sheet or tape materials is permitted, provided that it is protected from damage and is not subject to mechanical stress under normal use. Where more than one layer of insulation is used, there is no requirement for all layers to be of the same material. NOTE 1 One layer of insulation tape wound with more than 50 % overlap is considered to constitute two layers. NOTE 2 Basic, supplementary and double insulation can be applied as a pre-assembled system of thin materials.		P
4.4.7.8.3.2	Material thickness ≥ 0.2 mm		P
	Basic or supplementary insulation shall consist of at least one layer of material, which will meet the requirements of 4.4.7.8.1 and 4.4.7.10.1.		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Double insulation shall consist of at least two layers of material, each of which will meet the requirements of 4.4.7.8.1, 4.4.7.10.1, and the partial discharge requirements of 4.4.7.10.2, and both layers together will meet the impulse and a.c. or d.c. voltage requirements of 4.4.7.10.2.		P
	Reinforced insulation shall consist of a single layer of material, which will meet the requirements of 4.4.7.8.1 and 4.4.7.10.2.		P
	NOTE The requirements of this subclause indicate that double insulation can be at least 0.4 mm thick, while reinforced insulation is permitted to be 0.2 mm thick.		P
4.4.7.8.3.3	Material thickness less than 0.2 mm		P
	Basic or supplementary insulation shall consist of at least two layers of material, which will meet the requirements of 4.4.7.8.1 and 4.4.7.10.1.		P
	Double insulation shall consist of at least three layers of material. Each layer shall meet the requirements of 4.4.7.8.1 and 4.4.7.10.1, and any two layers together shall meet the requirements of 4.4.7.10.2.		P
	Reinforced insulation consisting of a single layer of material is not permitted.		P
4.4.7.8.3.4	Compliance		P
	Compliance shall be checked by the tests described in 5.2.3.1 to 5.2.3.5. When a component or sub-assembly makes use of thin sheet insulating materials, it is permitted to perform the tests on the component rather than on the material.		P
4.4.7.8.4	Printed wiring boards (PWBs)		P
4.4.7.8.4.1	General		P
	Insulation between conductor layers in double-sided single-layer PWBs, multi-layer PWBs and metal core PWBs, shall meet the requirements of 4.4.7.8.1. Basic, supplementary, double and reinforced insulation shall meet the appropriate requirements of 4.4.7.10.1 or 4.4.7.10.2. Functional insulation in PWBs shall meet the requirements of 4.4.7.7. For the inner layers of multi-layer PWBs, the insulation between adjacent tracks on the same layer shall be treated as either:		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	- a creepage distance for pollution degree 1 and a clearance as in air (see Example D.14); or - solid insulation, in which case it shall meet the requirements of 4.4.7.8.1 and 4.4.7.10.		
4.4.7.8.4.2	Use of coating materials	No coating materials	N/A
	A coating material used to provide functional, basic, supplementary and reinforced insulation shall meet the requirement as specified below.	No coating materials	N/A
	Type 1 protection (as defined in IEC 60664-3) improves the microenvironment of the parts under protection. The clearance and creepage distance of Table 10 and Table 11 for pollution degree 1 apply under the protection. Between two conductive parts, it is a requirement that one or both conductive parts, together with all the spacing between them, are covered by the protection.	No coating materials	N/A
	Type 2 protection is considered to be similar to solid insulation. Under the protection, the requirements for solid insulation specified in 4.4.7.8 are applicable, including the coating material itself, and spacings shall not be less than those specified in Table 1 of IEC 60664-3:2003. The requirements for clearance and creepage in Table 10 and Table 11 do not apply. Between two conductive parts, it is a requirement that both conductive parts, together with the spacing between them, are covered by the protection so that no air gap exists between the protective material, the conductive parts and the printed boards.	No coating materials	N/A
	The coating material used to provide Type 1 and Type 2 protection shall be designed to withstand the stresses anticipated to occur during the expected lifetime of the PECS. A type test on representative PWBs shall be conducted according to Clause 5 of IEC 60664-3:2003. For the cold test (5.7.1 of IEC 60664-3:2003), a temperature of -25 °C shall be used, and for the rapid change of temperature test (5.7.3 of IEC 60664-3:2003): -25 °C to +125 °C. No routine test is required.	No coating materials	N/A
4.4.7.8.5	Wound components		P
	Varnish or enamel insulation of wires shall not be used for basic, supplementary, double or reinforced insulation. Wound components shall meet the		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	requirements of 4.4.7.8.1 and 4.4.7.10. The component itself shall pass the requirements given in 4.4.7.8.1 and 4.4.7.10.2. If the component has reinforced or double insulation, the a.c. or d.c. voltage test of 5.2.3.4 shall be performed as a routine test.		
4.4.7.8.6	Potting materials	No such material.	N/A
	A potting material may be used to provide solid insulation or to act as a coating to protect against pollution.	No such material.	N/A
	If used as solid insulation, it shall comply with the requirements of 4.4.7.8.1 and 4.4.7.10.	No such material.	N/A
	If used to protect against pollution, the requirements for Type 1 protection in 4.4.7.8.4.2 apply.	No such material.	N/A
4.4.7.9	Connection of parts of solid insulation (Cemented joints)	No solid insulation used.	N/A
	The creepage and clearance path in the presence of a cemented joint between two insulating parts, are determined as follows. • Type 1 or type 2 protection as described in 4.4.7.8.4.2 apply. • A cemented joint that is not evaluated as providing protection of type 1 or type 2, is neither considered solid insulation nor to reduce pollution degree. The clearance and creepage distances of Table 10 and Table 11 apply for the pollution degree of the environment around the joint. See 5.2.5.7 for test.	No solid insulation used.	N/A
4.4.7.10	Requirements for electrical withstand capability		P
4.4.7.10.1	Basic or supplementary insulation	See Table 4.4.7.10	P
	Test with impulse withstand voltage according to 5.2.3.1		P
	Test with a.c. or d.c. voltage according to 5.2.3.4		P
4.4.7.10.2	Double and reinforced insulation	See Table 4.4.7.10	P
	Double or reinforced insulation shall be tested as follows: • Test with impulse withstand voltage according to 5.2.3.2; and • Test with a.c. or d.c. voltage according to 5.2.3.4.		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	For solid insulation, the partial discharge test according to 5.2.3.5 shall be performed in addition to the above tests, if the recurring peak working voltage across the insulation is greater than 750 V and the voltage stress on the insulation is greater than 1 kV/mm. The partial discharge test shall be performed as a type test on all components, sub-assemblies and PWB. In addition, a sample test shall be performed if the insulation consists of a single layer of material.		P
	Double insulation shall be designed so that failure of the basic insulation or of the supplementary insulation will not result in reduction of the insulation capability of the remaining part of the insulation.		P
4.4.7.11	Insulation requirements above 30 kHz		N/A
4.4.8	Compatibility with residual current-operated protective devices		N/A
	To ensure the intended work of an RCD provided by the installation PECS shall satisfy one of the following conditions. a) A Pluggable Type A single-phase PECS, shall be designed so that, under normal and fault conditions any resulting d.c. component of the current in the PE conductor does not exceed the d.c. current withstand requirements in IEC 60755 for RCD of type A. b) For PECS that are Pluggable Type B or intended for permanent connection, d.c. current in the PE conductor is not limited if the information and marking requirements of 6.3.7.4 are complied with.		N/A
	Compliance with RCD provided by the installation shall be checked by simulation or calculation of current in the PE conductor under normal and single fault conditions according to the guideline provided in Annex H.		N/A
4.4.9	Capacitor discharge		P
	For protection against shock hazard, capacitors within a PECS shall be discharged to a voltage less than DVC As, or to a residual charge less than 50 μ C, after the removal of power from the PECS: • For pluggable PECS type A and B the discharge time shall not exceed 1 s or the hazardous live parts shall be protected against direct contact by at least IPXXB (see	Symbol and an indication of the discharge time used in a clearly visible position.  	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	4.4.3.3). • For permanently connected PECS the discharge time shall not exceed 5 s. For pluggable PECS type A and B and permanently connected PECS, which do not meet the above requirements, access shall only be possible by means of a tool or key and the information and marking requirements of 6.5.2 apply. Compliance is checked by test of 5.2.3.8.		
4.5	Protection against electrical energy hazards		P
4.5.1	Operator Access Areas		P
4.5.1.1	General	No such kind of hazard.	P
	Equipment shall be so designed that there is no risk of electrical energy hazard in operator access areas from accessible circuits by fulfilling requirement of 4.2. A risk of injury due to an electrical energy hazard exists if it is likely that two or more bare parts (one of which may be earthed) between which a hazardous energy level exists, will be bridged by a metallic object. The likelihood of bridging the parts under consideration is determined by means of the test finger of Figure 1 of IEC 60529:1989, in a straight position. If it is possible to bridge the parts with this test finger, a hazardous energy level shall not exist. Barriers, guards, and similar means preventing unintentional contact may be provided as an alternative to limiting the energy.	Equipment is designed that there is no risk of electrical energy hazard in operator access areas from accessible circuits by fulfilling requirement of 4.2.	P
	Compliance is checked by inspection or test of 5.2.2.2.	Fulfil requirements	P
4.5.1.2	Determination of hazardous energy level		P
	A hazardous electrical energy level is considered to exist if: • the voltage is 2 V or more; and • power available exceeds 240 VA after 60 s; or • the energy exceeds 20 J. Compliance shall be checked with the test in 5.2.3.9 or by calculation.		P
4.5.2	Service Access Areas	Symbol and an indication of the discharge time used in a clearly visible position.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Capacitors within a PECS shall be discharged to an energy level less than 20 J, as in 4.5.1.2, within 5 s after the removal of power from the PECS. If this requirement is not achievable for functional or other reasons, the information and marking requirements of 6.5.2 apply.		P
	If the capacitor discharge time cannot be accurately calculated, the discharge time shall be measured.		P
4.6	Protection against fire and thermal hazards		P
4.6.1	Circuits representing a fire hazard		P
	The following types of circuits are considered a fire hazard: - circuits directly connected to the mains - circuits that are not directly connected to the mains but exceed the limits for limited power sources in 4.6.5 - components having unenclosed arcing parts		P
4.6.2	Components representing a fire hazard		P
4.6.2.1	General	Considered.	P
	Compliance with 4.6.2 and 4.6.3 shall be confirmed by inspection of component and material data sheets and, where necessary, by test.	Fulfil requirements	P
4.6.2.2	Components within a circuit representing a fire hazard		P
	Inside fire enclosures, materials for components and other parts and all materials in contact with such parts shall comply with flammability class V-2 as classified in IEC 60695-11-10 or flammability class HF-2 as classified in ISO 9772 or better.	Fulfil requirements	P
	The above requirement does not apply to any of the following: • electrical components which do not present a fire hazard under abnormal operating conditions when tested according to 5.2.4.6; • materials and components within an enclosure of 0.06 m ³ or less, consisting totally of metal and having no ventilation openings, or within a sealed unit containing an inert gas; • electronic components, such as integrated circuit packages, opto-coupler packages, capacitors and other small parts that are		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	mounted on material of flammability class V-1 or better; - wiring, cables and connectors insulated with PVC, TFE, PTFE, FEP, neoprene or polyimide; - the following parts, provided that they are separated from electrical parts (other than insulated wires and cables) which under fault conditions are likely to produce a temperature that could cause ignition, by at least 13 mm of air or by a solid barrier of material of flammability class V-1 or better: - other small parts which would contribute negligible fuel to a fire, including, labels, mounting feet, key caps, knobs and the like; - tubing for air or any fluid systems, containers for powders or liquids and foamed plastic parts, provided that they are of flammability class HB.		
4.6.2.3	Components within a circuit not representing a fire hazard		P
	For components within a circuit not representing a fire hazard 4.6.2 does not apply.		P
4.6.3	Fire enclosures		P
4.6.3.1	General	Considered.	P
	Fire enclosures are used to reduce the risk of fire to the environment, independent of the location where they are installed. A fire enclosure shall be provided for all PECS unless: - the product committee specifies that a fire enclosure is not required; or - there is an agreement between the user and the manufacturer; or - the PECS is intended to be used only in areas without combustible materials and is marked according to 6.3.5.	Metal enclosure	P
4.6.3.2	Flammability of enclosure materials	Considered.	P
	Materials used for fire enclosures of PECS shall meet the flammability test requirements of 5.2.5.5, except for those portions of the enclosure that enclose only circuits not representing a fire hazard.		N/A
	Materials are considered to comply without test if, in the minimum thickness used, the		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	material is of flammability class 5VA or better, according to IEC 60695-11-20.		
	Metals, ceramic materials, and glass which is heat-resistant tempered, wired or laminated, are considered to comply without test.		P
	Materials for components that fill an opening in a fire enclosure shall: • be of at least V-1 class material and no larger than 100 mm in any dimension; or • be of at least V-2 class material and either – not larger than 25 mm in any dimension; or – not larger than 100 mm in any dimension and located at least 100mm from any part that is a source of fire hazard; or • be of at least V-2 class material and there is a barrier or device(s) that forms a barrier made of a V-0 class material between the part and a source of fire hazard; or • comply with a relevant IEC component standard that includes flammability requirements for components that are intended to form part of, or fill openings in, a fire enclosure.		P
	Polymeric materials that serve as the outer enclosure and have surface area greater than 1 m ² or a single dimension larger than 2 m, shall have a maximum flame spread index of 100 as determined by ASTM E162 or ANSI/ASTM E84.		P
	The manufacturer may provide data from the fire enclosure material supplier to demonstrate compliance with the above requirements. In this case, no further testing is required.		P
	Compliance shall be checked by visual inspection and, where necessary, by test.		P
4.6.3.3	Openings in fire enclosures		N/A
4.6.3.3.1	General		N/A
4.6.3.3.2	Openings in the top and the side of fire enclosures		N/A
	Openings in the top surfaces of fire enclosures shall be designed to prevent an external object falling vertically or at up to 5° from vertically from entering the enclosure in an area that could lead to a fire hazard. This requirement applies to all sides of		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	moveable equipment with no defined top and bottom, unless top and bottom surfaces can be suitably demonstrated in the installation instructions. Compliance shall be checked by test of 5.2.2.2.		
	Openings in the top surfaces of fire enclosures not located vertically above or within 5° from vertical of a circuit representing a fire hazard as defined in 4.6.1 are not subject to the test of 5.2.2.2 and can be of any construction if the construction prevents access to parts greater than DVC As with the IP3X probe as detailed in 4.4.3.3. Where a portion of the side of a fire enclosure falls within the area traced out by the 5° angle in Figure 6, the limitations in 4.6.3.3.3 regarding openings in bottoms of fire enclosures also apply to this portion of the side. Compliance shall be checked by visual inspection.		N/A
4.6.3.3.3	Openings in the bottom of fire enclosures	No openings in the bottom of fire enclosures	N/A
	Compliance is checked by inspection or with the hot flaming oil test in 5.2.5.6, in case the fire enclosure is designed differently than as described in this subclause.	No openings in the bottom of fire enclosures	N/A
4.6.3.3.4	Doors of covers in fire enclosures		P
	If part of a fire enclosure consists of a door or a cover leading to an operator access area, it shall comply with one of the following requirements: • the door or cover shall be provided with a safety interlock; or • a door or cover, intended to be routinely opened by the user, shall comply with both of the following conditions: – it shall not be removable from other parts of the fire enclosure by the user; and – it shall be provided with a means to keep it closed during normal operation. A door or cover intended only for occasional use by an installer, such as for the installation of accessories, is permitted to be removable provided that the equipment instructions include directions for correct removal and reinstallation of the door or cover.	The door shall be opened by a lock	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Compliance is checked by inspection.		
4.6.4	Temperature limits		P
4.6.4.1	Internal parts	See table 4.6.4	P
	Equipment and its component parts shall not attain temperatures in excess of those in Table 14 when tested in accordance with the ratings of the equipment. Compliance is checked by test of 5.2.3.10.		P
4.6.4.2	Accessible parts	See table 4.6.4	P
	When surface temperatures of the PECS, close to mounting surfaces, exceed the limit of Table 15, a warning according to 6.3.5 shall be provided.		P
4.6.5	Limited power sources	Not limited power sources	N/A
	Where a limited power source is required, the source shall comply with Table 16 or Table 17 as applicable.		N/A
	A limited power source shall comply with one of the following requirements: a) the output is inherently limited in compliance with Table 16; or b) a linear or non-linear impedance limits the output in compliance with Table 16. If a positive temperature coefficient device (e.g. PTC) is used, it shall pass the applicable tests specified in IEC 60730-1; or c) a regulating network limits the output in compliance with Table 16, both with and without a single fault in the regulating network; or d) an overcurrent protective device is used and the output is limited in compliance with Table 17.		N/A
	Compliance to determine the maximum available power is checked by test of 5.2.3.9.		N/A
4.7	Protection against mechanical hazards		P
4.7.1	General		P
	Failure of any component within the PECS shall not release sufficient energy to lead to a hazard, for example, expulsion of material into an area occupied by personnel.		P
4.7.2	Specific requirements for liquid cooled PCS		P
4.7.2.1	General	liquid cooling	P
4.7.2.2	Coolant		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Coolant temperature in operation shall not exceed the limit specified in Table 14.	The cooling system can monitor the temperature of coolant, the coolant is glycol aqueous solution, maximum temperature is 55°C, if the temperature exceed the limit, the unit will alarm and protected.	P
	Compliance is checked by inspection and test of 5.2.3.10.		P
4.7.2.3	Design requirements		P
4.7.2.3.1	General		P
	The liquid containment system components shall be compatible with the liquid to be used. Equipment using liquids shall be so constructed that it is unlikely that either a dangerous concentration of these materials or a hazard in the meaning of this standard will be created by condensation, vaporization, leakage, spillage or corrosion during normal operation, storage, filling or emptying. Compliance is checked by inspection. The flexible hoses should be made of material free of conductive contaminants such as carbon.		P
4.7.2.3.2	Corrosion requirements		P
	All cooling system components shall be suitable for use with the specified coolant. They shall be corrosion resistant and shall not corrode as a result of prolonged exposure to the coolant and/or air. Compliance is checked by inspection.		P
4.7.2.3.3	Tubing, joints and seals		P
	Cooling system tubing, joints and seals shall be designed to prevent leakage during excursions of pressure over the life of the equipment. The entire cooling system including tubing shall satisfy the requirements of the hydrostatic pressure test of 5.2.7.	2 times the operating pressure rating of the system is achieved	P
4.7.2.3.4	Provision for condensation		P
	Where internal condensation occurs during normal operation or maintenance, measures shall be taken to prevent degradation of insulation. In those areas where such condensation is expected, clearance and creepage distances of Table 10 and Table 11 shall be evaluated at least for a pollution	If condensation occurred, the unit will protect, refer to single fault test	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	degree 3 environment (see Table 8), and provision shall be made to prevent accumulation of water (for example by providing a drain). Compliance is checked by inspection.		
4.7.2.3.5	Leakage of coolant		P
	During a leakage measures has to ensure that coolant will not result in wetting of live parts or electrical insulation.	If leakage occurred, the unit will protect and disconnect the input power, refer to single fault test	P
4.7.2.3.6	Loss of coolant		P
	Loss of coolant form the cooling system shall not result in thermal hazards, explosion, or shock hazard. The requirements of the Loss of coolant test of 5.4.3.9.4 shall be satisfied.		P
4.7.2.3.7	Conductivity of coolant		N/A
	When the coolant is intentionally in contact with live parts (for example non-earthed heatsinks), the conductivity of the coolant shall be continuously monitored and controlled, in order to avoid hazardous current flow through the coolant.	Coolant without contact with live parts	N/A
4.7.2.3.8	Insulation requirements for coolant hoses		N/A
	When the coolant is intentionally in contact with live parts (for example non-earthed heatsinks), the coolant hoses form a part of the insulation system. Depending on the location of the hoses, the requirements of 4.4.7 for functional or simple or protective separation shall be applied where relevant.	Coolant without contact with live parts	N/A
4.8	Equipment with multiple sources of supply		P
	Equipment with more than one supply; design shall be: - separate means of connection are provided for different circuits; and - supply plug connections, if any, are not interchangeable if a hazard could be created by incorrect plugging; and - hazards, within the meaning of this standard, shall not be present under normal or single fault conditions due to the presence of multiple sources of supply. Actions such as disconnection or de-energizing of a supply are considered a normal condition. Compliance is checked by the evaluation of		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	4.2		
	Examples of the types of hazards that should be considered are: a) Backfeed prevention – preventing voltage or energy available within the PECS or one of its sources from being fed back to any of the input terminals for another source, either directly or by a leakage path. b) Protection against unintentional islanding. c) Touch current levels may be higher with multiple sources connected simultaneously. d) Hazard resulting from damage to one or more connected sources due to energy from another source, for example the mains. e) Damage to wiring due to currents higher than the wiring is designed for flowing from another source.		P
4.9	Protection against environmental stresses		P
	The manufacturer has to specify the following conditions for operation, storage and transportation according to IEC 60721: - Coolant temperature (min/max); - Ambient temperature (min/max); - Humidity (min/max) - Pollution degree; - Vibration; - U.V. resistance; - Over voltage category (OVC); - Altitude for thermal consideration, if rated for operation above 1000 m; - Altitude for insulation coordination considerations, if rated for operation above 2000 m.	Considered.	P
	The manufacturer shall state the environmental service condition for the PECS according to Table 18.	The manufacturer state the environmental service condition for the PECS according to Table 18.	P
4.10	Protection against Sonic Pressure Hazards		P
4.10.1	General		P
4.10.2	Sonic pressure and sound level	See below.	P
	If the measured sound pressure exceeds 70 dBA (except that sounds from alarms are not included) the documentation shall provide	The warning information was provided about the sound level of the equipment.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	information regarding the sound level of the equipment.		
4.11	Wiring and connections		P
4.11.1	General		P
	The wiring and connections between parts of the equipment and within each part shall be protected from mechanical damage during installation. The insulation, conductors and routing of all wires of the equipment shall be suitable for the electrical, mechanical, thermal and environmental conditions of use. Conductors which are able to contact each other shall be provided with insulation rated for the DVC requirements of the relevant circuits. The compliance with 4.11.2 to 4.11.8 shall be checked by inspection (see 5.2.1) of the overall construction and datasheets if applicable.	The wiring and connections between parts of the equipment and within each part is protected from mechanical damage during installation.	P
4.11.2	Routing	Considered.	P
	A hole through which insulated wires pass in a sheet metal wall within the enclosure of the equipment shall be provided with a smooth, well-rounded bushing or grommet or shall have smooth, well-rounded surfaces upon which the wires bear to reduce the risk of abrasion of the insulation.	A hole through which insulated wires pass in a sheet metal wall within the enclosure of the equipment is provided with a smooth, well-rounded bushing or grommet	P
	Wires shall be routed away from sharp edges, screw threads, burrs, fins, moving parts, drawers, and similar parts, which abrade the wire insulation. The minimum bend radius specified by the wire manufacturer shall not be violated.	Wires are routed away from sharp edges, screw threads, burrs, fins, moving parts, drawers, and similar parts.	P
	Clamps and guides, either metallic or non-metallic, used for routing stationary internal wiring shall be provided with smooth, well-rounded edges. The clamping action and bearing surface shall be such that abrasion or deformation of the insulation does not occur. If a metal clamp is used for conductors having thermoplastic insulation less than 0.8 mm thick, non-conduction mechanical protection shall be provided.	Clamps and guides is provided with smooth, well-rounded edges.	P
4.11.3	Colour coding	Considered.	P
	Insulated conductors, other than those which are integral of ribbon cable or multi-cord signal cable, identified by the colour green with or without one or more yellow stripes shall only be used for protective bonding.		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
4.11.4	Splices and connections	Considered.	P
	All splices and connections shall be mechanically secured and shall provide electrical continuity. Electrical connections shall be soldered, welded, crimped, or otherwise securely connected. A soldered joint, other than a component on a PWB, shall additionally be mechanically secured. <i>NOTE Stranded wire should not be consolidated with solder where secured in a terminal that relies on pressure for contact or equivalent</i> When stranded internal wiring is connected to a wire-binding screw, the construction shall be such that loose strands of wire do not contact: • other uninsulated live parts not always of the same potential as the wire; • de-energized metal parts. When screw terminal connections are used, the resulting connections may require routine maintenance (tightening). Appropriate reference shall be made in the maintenance manual (see 6.5.1).	Fulfil requirements	P
4.11.5	Accessible connections	Considered.	P
	In addition to measures given in 4.4.6.4 it shall be ensured that neither insertion error nor polarity reversal of connectors can lead to a voltage on an accessible connection higher than the maximum of DVC As. This applies for example to plug-in sub-assemblies or other plug-in devices which can be plugged in without the use of a tool or key or which are accessible without the use of a tool or key. This does not apply to equipment intended to be installed in restricted access areas. If relevant, non-interchangeability and protection against polarity reversal of connectors, plugs and socket outlets shall be confirmed by inspection and trial insertion.	Considered.	P
4.11.6	Interconnections between parts of the PCS	Considered.	P
	In addition to complying with the requirements given in 4.11.1 to 4.11.5, the means provided for the interconnection between parts of the PECS shall comply with the following requirements or those of 4.11.7. Cable assemblies and flexible cords provided for interconnection between	Fulfil requirements	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	sections of equipment or between units of a system shall be suitable for the service or use involved. Cables shall be protected from physical damage as they leave the enclosure and shall be provided with mechanical strain relief. Misalignment of male and female connectors, insertion of a multipin male connector in a female connector other than the one intended to receive it, and other manipulations of parts which are accessible to the operator shall not result in mechanical damage or a risk of thermal hazards, electric shock, or injury to persons. When external interconnecting cables terminate in a plug which mates with a receptacle on the external surface of an enclosure, no risk of electric shock shall exist at accessible contacts of either the plug or receptacle when disconnected. <i>NOTE An interlock circuit in the cable to de-energize the accessible contacts whenever an end of the cable is disconnected meets the intent of these requirements.</i>		
4.11.7	Supply connections	Considered.	P
	The connection points provided shall be of appropriate construction to preclude the possibility of loose strands reducing the spacing between conductors when careful attention is paid to installation.	The connection points provided is of appropriate construction to preclude the possibility of loose strands reducing the spacing between conductors when careful attention is paid to installation.	P
4.11.8	Terminals		P
4.11.8.1	Construction requirements	Considered.	P
	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength. Terminal connections shall be such that the conductors can be connected by means of screws, springs or other equivalent means so as to ensure that the necessary contact pressure is maintained. Terminals shall be so constructed that the conductors can be clamped between suitable surfaces without any significant damage either to conductors or terminals. Terminals shall not allow the conductors to be displaced or be displaced themselves in a manner detrimental to the operation of equipment and the insulation shall not be reduced below the rated values.	All parts of terminals which maintain contact and carry current is of metal having adequate mechanical strength.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	The requirements of this subclause are met by using terminals complying with IEC 60947-7-1 or IEC 60947-7-2, as appropriate.		
4.11.8.2	Connecting capacity	Considered.	P
	Terminals shall be provided which accommodate the conductors specified in the installation and maintenance manuals (see 6.3.6.4) and cables in accordance with the wiring rules applicable at the installation. The terminals shall meet the temperature rise test of 5.2.3.10.	Terminals is provided which accommodate the conductors specified in the user manuals (see 6.3.6.4) and cables in accordance with the wiring rules applicable at the installation. The terminals shall meet the temperature rise test of 5.2.3.10.	P
	Information regarding the permitted wire sizes shall be given in the installation manual.	Information regarding the permitted wire sizes is given in the user manual.	P
4.11.8.3	Connection	Considered.	P
	Terminals for connection to external conductors shall be readily accessible during installation. Sets of terminals for connection to the same input or output shall be grouped together and shall be located in proximity to each other and to the main protective earthing terminal, if any. If the installation instructions provide detail on the proper earthing of the system, the protective earthing terminal need not be placed in proximity to the terminals. Clamping screws and nuts shall not serve to fix any other component although they may hold the terminals in place or prevent them from turning.	Terminals for connection to external conductors is readily accessible during installation.	P
4.11.8.4	Wire bending space for wires 10 mm ² and greater	Fulfil requirements	P
	The distance between a terminal for connection to the main supply, or between major parts of the PECS (for example a transformer), and an obstruction toward which the wire is directed upon leaving the terminal shall be at least that specified in Table 19.	Fulfil requirements	P
4.12	Enclosures		P
4.12.1	General		P
4.12.2	Handles and manual controls		P
	Handles, knobs, grips, levers and the like shall be reliably fixed so that they will not work loose in normal use, if this could result in a hazard. Sealing compounds and the like,		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	other than self-hardening resins, shall not be used to prevent loosening. If handles, knobs and the like are used to indicate the position of switches or similar components, it shall not be possible to fix them in a wrong position if this could result in a hazard.		
4.12.3	Cast metal		N/A
	Die-cast metal, except at threaded holes for conduit, where a minimum of 6.4 mm thickness is required, shall be: • not less than 2.0 mm thick for an area larger than 155 cm² or having any dimension larger than 150 mm; • not less than 1.2 mm thick for an area of 155 cm² or less and having no dimension larger than 150 mm. The area under evaluation may be bounded by reinforcing ribs subdividing a larger area. Malleable iron or permanent-mould cast aluminium, brass, bronze, or zinc, except at threaded holes for conduit, where a minimum of 6.4 mm thickness is required, shall be: • at least 2.4 mm thick for an area greater than 155 cm² or having any dimension more than 150 mm; • at least 1.5 mm thick for an area of 155 cm² or less having no dimension more than 150 mm. A sand-cast metal enclosure shall be a minimum of 3.0 mm thick except at locations for threaded holes for conduit, where a minimum of 6.4 mm is required.		N/A
4.12.4	Sheet metal		P
4.12.5	Stability	Fixed appliance	P
	Under conditions of normal use, units and equipment shall not become physically unstable to the degree that they could become a hazard to an operator or to a service person. If units are designed to be fixed together on site and not used individually, the stability of each individual unit is exempt from the requirements of 4.12.5. The requirements of 4.12.5 are not applicable if the installation instructions for a unit specify that the equipment is to be secured to the building structure before operation. Under conditions of operator use, a	Fixed appliance	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	stabilizing means, if needed, shall be automatic in operation when drawers, doors, etc., are opened. During operations performed by a service person, the stabilizing means, if needed, shall either be automatic in operation, or a marking shall be provided to instruct the service person to deploy the stabilizing means. Compliance is checked by test of 5.2.2.5.		
5	TEST REQUIRMENTS		P
5.1	General		P
5.1.1	Test objectives and classification	Type tests	P
5.1.2	Selection of test samples		P
5.1.3	Sequence of tests	Considered.	P
5.1.4	Earthing conditions	Considered.	P
5.1.5	General conditions for tests		P
5.1.5.1	Application of tests		P
	Unless otherwise stated, upon conclusion of the tests, the equipment need not be operational.		P
5.1.5.2	Test samples	Considered.	P
5.1.5.3	Operating parameters for tests	Considered.	P
5.1.6	Compliance		P
5.1.7	Test overview		P
5.2	Test specifications		P
5.2.1	Visual inspections (type test, sample test and routine test)	Fulfil requirements	P
	Before type testing, a check shall be made that the PECS delivered for the test is as expected with respect to supply voltage, input and output ranges, etc.	Considered.	P
5.2.2	Mechanical tests		P
5.2.2.1	Clearances and creepage distance (type test)		P
	It shall be verified by measurement or visual inspection that the clearance and creepage distances comply with 4.4.7.4 and 4.4.7.5.	See table 4.4.7.4 and 4.4.7.5	P
	Where this verification is impossible to perform, an impulse voltage test (see 5.2.3.2) shall be performed between the considered circuits.		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
5.2.2.2	Non-accessibility test (type test)		P
	This test is intended to show that live parts, protected by means of enclosures and barriers in compliance with 4.4.3.3, are not accessible.	Considered	P
	This test shall be performed as a type test of the enclosure of a PCS as specified in IEC 60529 for the enclosure classification for protection against access to hazardous parts.	Considered	P
	Except as noted below: •The test probe for IP3X shall not penetrate the top surface of the enclosure when probed from the vertical direction $\pm 5^\circ$ only.		P
5.2.2.3	Ingress protection test (IP rating) (type test)		P
	The claimed IP rating of the enclosure shall be verified. This test shall be performed as a type test of the enclosure of a PCS as specified in IEC 60529 for the enclosure classification.	See model list	P
5.2.2.4	Enclosure integrity test (type test)		P
5.2.2.4.1	General	Considered	P
	The integrity tests apply to PCS, and also where PCS are intended for operation without a further enclosure in restricted access areas. After completion of the integrity test, the PCS shall pass the tests of 5.2.3.2 and 5.2.3.4 and shall be inspected to confirm that:	Fulfil requirements	P
	- no degradation of any safety-relevant component of the PCS has occurred.	No degradation of any safety-relevant component of the PCS has occurred.	P
	- live parts have not become accessible (see 4.4.3.3).	see 4.4.3.3	P
	- enclosures show no cracks or openings which could cause a hazard.	Enclosures show no cracks or openings which could cause a hazard.	P
	- clearances are not less than their minimum permitted values and other insulation is undamaged.	Clearances are not less than their minimum permitted values and other insulation is undamaged	P
	- barriers have not been damaged or loosened.	Barriers have not been damaged or loosened.	P
	- no moving parts which could cause a hazard are exposed.	No moving parts which could cause a hazard are exposed.	P
	The integrity tests shall be performed at the		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	worst case point on representative accessible face(s) of the enclosure.		
	The PCS is not required to be operational after testing and the enclosure may be deformed to such an extent that its original IP rating is not maintained.	Extent that its original IP rating is maintained.	P
5.2.2.4.2	Deflection test (type test)		P
5.2.2.4.2.1	General	Metal and approved plastic used enclosure used	P
	If requested by 4.12.1 the test in 5.2.2.4.2.2 and 5.2.2.4.2.3 applies, for metallic enclosure, as applicable.		P
5.2.2.4.2.2	Steady force test, 30 N	Complied.	P
5.2.2.4.2.3	Steady force test, 250 N	Complied.	P
5.2.2.4.3	Impact test (type test)		N/A
5.2.2.4.4	Drop		N/A
	Transportable equipment ≤ 18 kg Drop three times from 1000 mm on a horizontal surface at locations where they provide the most adverse results.		N/A
5.2.2.4.5	Stress relief		N/A
5.2.2.5	Stability test		P
5.2.2.6	Wall or ceiling mounted equipment		N/A
5.2.2.7	Handles and manual controls securement		P
5.2.3	Electrical tests		P
5.2.3.1	General	See Table 4.4.7.10	P
	The electrical tests described in 5.2.3.2 to 5.2.3.5 are applicable to basic, supplementary and reinforced insulation. Before performing these tests, preconditioning according to 5.2.6.3.1 and 5.2.6.3.2 is required.	Complied.	P
	When performing electrical and preconditioning tests, the preferred procedure is to test the entire equipment; however it is acceptable to test the components or sub-assemblies providing the basic and reinforced insulation. When components or sub-assemblies are tested, test conditions shall simulate the least favourable conditions occurring inside the equipment at the place of installation.	Complied.	P
5.2.3.2	Impulse voltage test (type test and sample	See Table 4.4.7.10	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	test)		
5.2.3.3	Alternative to Impulse voltage test (type test and sample test)	Impulse voltage test	N/A
	An a.c. or d.c. voltage test according to 5.2.3.4 may be used as an alternative method to the impulse voltage test of 5.2.3.2.	Impulse voltage test	N/A
	For an a.c. voltage test the peak value of the a.c. test voltage shall be equal to the impulse test of Table 25 and applied for three cycles of the a.c. test voltage.	Impulse voltage test	N/A
	For a d.c. voltage test the average value of the d.c. test voltage shall be equal to the impulse test voltage of Table 25 and applied three times for 10 ms in each polarity.	Impulse voltage test	N/A
	See IEC60664-1 clause 6.1.2.2.2 for further information.	Impulse voltage test	N/A
5.2.3.4	A.C. or d.c. voltage test (type test and routine test)		P
5.2.3.4.1	Purpose of test		P
	The test is used to verify that the clearances and solid insulation of components and of assembled PCS has adequate dielectric strength to resist temporary overvoltage conditions.	Complied.	P
5.2.3.4.2	Value and type of test voltage	See Table 4.4.7.10	P
	The values of the test voltage for circuits connected to mains supply are determined from column 2 or 3 of Table 26. The voltage test shall be performed with a sinusoidal voltage at 50 Hz or 60 Hz. If the circuit contains capacitors the test may be performed with a d.c. voltage of a value equal to the peak value of the specified a.c. voltage.	See Table 4.4.7.10	P
5.2.3.4.3	Performing the voltage test	See table 4.4.7.10	P
	a) Test (1) between accessible conductive part 8connected to earth) and each circuit sequentially (except DVC As circuits). Test voltage according to Table 26, or Table 27, column 2, corresponding to voltage of considered circuit under test. Test (2) between accessible surface (nonconductive or conductive but not connected to earth9 and each circuit sequentially (except DVC As circuits). Test voltage according to Table 26 or Table 27, column 3 (for	See table 4.4.7.10	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	type test) or column 2 (for routine test), corresponding to voltage of considered circuit under test.		
	b) Test between each considered circuit sequentially and the other adjacent circuits connected together. Test voltage according to Table 26 or Table 27, column 2, corresponding to voltage of considered circuit under test.	See table 4.4.7.10	P
	c) Test between DVC As circuit and each adjacent circuit sequentially. Test voltage according to Table 26 or Table 27, column 3 (for type test) or column 2 (for routine test), corresponding to the circuit with the higher voltage. Either the adjacent circuit or the DVC As circuit may be earthed for this test. It is necessary to test functional insulation between PELV and SELV circuits, but it is not necessary to test functional insulation between adjacent PELV or adjacent SELV circuits.	See table 4.4.7.10	P
5.2.3.4.4	Duration of the a.c. or d.c. voltage test		P
	The duration of the test shall be at least 60 s for the type test and 1 s for the routine test. The test voltage may be applied with increasing and/or decreasing ramp voltage but the full voltage shall be maintained for 60 s and 1 s respectively for type and routine tests.	60s	P
5.2.3.4.5	Verification of the a.c. or d.c. voltage test	See table 4.4.7.10	P
	The test is successfully passed if no electrical breakdown occurs during the test.	See table 4.4.7.10	P
5.2.3.5	Partial discharge test (type test, sample test)		N/A
	The partial discharge test shall confirm that the solid insulation (see 4.4.7.8) used in components and subassemblies for protective separation of electrical circuits remains partial-discharge-free within the specified voltage range (see Table 28).		N/A
	This test shall be performed as a type test and a sample test. It may be omitted for insulating materials which are not degraded by partial discharge, for example ceramics. The partial discharge inception and extinction voltage are influenced by climatic factors (e.g. temperature and moisture), equipment self-heating, and manufacturing		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	tolerance. These influencing variables can be significant under certain conditions and shall therefore be taken into account during type testing.		
5.2.3.6	Protective impedance (type test and routine test)		N/A
	A type test shall be performed to verify that the current through a protective impedance under normal operating or single-fault conditions does not exceed the values given in 4.4.3.4. The test shall be performed using the circuit of IEC 60990:1999, Figure 4. NOTE IEC 60990 states that the use of a single network for the measurement of a.c. combined with d.c. has not been investigated, but no suggestion is made for measurement in such cases. The value of the protective impedance shall be verified as a routine test.		N/A
5.2.3.7	Touch current measurement (type test)		P
	The touch current shall be measured to determine if the measures of protection need not be taken (see 4.4.4.3.3). The PECS shall be set up in an insulated state without any connection to the earth and shall be operated at rated voltage. Under these conditions, the touch current shall be measured between the means of connection for the PE conductor and the PE conductor itself with the test circuit of Figure 4 of IEC 60990:1999.	Clause 4.4.4.3.3 consider	P
	• For a PCS to be connected to an earthed neutral system, the neutral of the mains of the test site shall be directly connected to the protective earthing conductor.		N/A
	• For a PCS to be connected to an earthed neutral system, the neutral shall be connected through a resistance of 1 kΩ to the protective earthing conductor which shall be connected to each input phase in turn. The highest value will be taken as the definitive result.		N/A
	• For a PCS to be connected to a corner earthed system, the protective earthing conductor shall be connected to each input phase in turn. The highest value will be taken as the definitive result.	TN system	P
	• For a PCS with a particular earthing system, this system shall operate as intended during the test.		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	If a PCS is intended to be connected to more than one system network, each of these different system networks (or the worst-case, if that can be determined) shall be used to make the touch current measurement.		N/A
5.2.3.8	Capacitor discharge (type test)		P
	The capacitor discharge time as required by 4.4.3.4 may be verified by a type test and/or by calculation taking into account the relevant tolerances.	Symbol and an indication of the discharge time used in a clearly visible position	P
5.2.3.9	Limited power source test (type test)	Not limited power source	N/A
	When required by 4.6.5 a limited power circuit shall be tested as below, with the equipment operating under normal operating conditions. In case the limited power source requirement depends on overcurrent protective device(s), the device(s) shall be short-circuited. With the equipment operating under normal operating conditions, a variable resistive load is connected to the parts under consideration and adjusted to obtain a level required limited VA power. Further adjustment is made, if necessary, to maintain the limited VA power for a period specified by 4.6.5. A variable resistive load is connected to the circuit under consideration and adjusted to obtain the limit of apparent power as indicated in Table 16 or Table 17, as applicable. Further adjustment is made, if necessary, to maintain the limit of apparent power for the time period indicated in Table 16 or Table 17, as applicable. The test is passed, if after the test period the available apparent power does not exceed the limits indicated in Table 16 or Table 17, as applicable. In case the limited power source requirement depends on overcurrent protective device(s), the current rating of at least one of the protective device(s) in the current path shall not exceed the limit in Table 17.		N/A
5.2.3.10	Temperature rise test (type test)	See table 4.6.4	P
	If possible the PECS must operate in the worst conditions of the rated power and the output current.		P
	Equipment, in which the heating or cooling quantity depends on the temperature, the	Maximum environment temperature of EUT is 55°C.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	temperature measurement must be carried out under the most unfavourable conditions of ambient temperature within the range specified by the manufacturer.		
	The PECS shall be tested with at least 1.2 m of wire attached to each field wiring terminal. The wire shall be of the smallest size intended to be connected to the PECS as specified by the manufacturer for installation. When there is only provision for the connection of bus-bars to the PECS, they shall be of the minimum size intended to be connected to the PECS as specified by the manufacturer, and they shall be at least 1.2 m in length.	Considered	P
	The test shall be maintained until thermal stabilization has been reached. That is, when three successive readings, taken at intervals of 10 % of the previously elapsed duration of the test and not less than 10 min. intervals, indicate no change in temperature, defined as $\pm 1^{\circ}\text{C}$ between any of the three successive readings, with respect to the ambient temperature.	The test is maintained until thermal stabilization has been reached	P
	The temperature of an electrical insulation (other than that of windings) is measured on the surface of the insulation at a point close to the heat source, if a failure of this insulation could cause a hazard. If temperatures of windings are measured by the thermocouple method, the thermocouple shall be located on the surface of the winding assuming the hottest part due to surrounding heat emitting components. See also notes in Table 14.	The temperature of an electrical insulation (other than that of windings) is measured on the surface of the insulation at a point close to the heat source	P
	The maximum temperature attained shall be corrected to the rated ambient temperature of the PCS by adding the difference between the ambient temperature during the test and the maximum rated ambient temperature.	The maximum temperature attained is corrected to the rated ambient temperature of the PCS by adding the difference between the ambient temperature during the test and the maximum rated ambient temperature.	P
	No corrected temperature shall exceed the rated temperature of the material or component measured.	No corrected temperature is exceed the rated temperature of the material or component measured.	P
	During the test, thermal cut-out, overload detection functions and devices shall not operate.	During the test, thermal cut-out, overload detection functions and devices is not operate.	P
5.2.3.11	Protective bonding tests (type tests and routine test)		P
5.2.3.11.1	General		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Each conductive accessible part under consideration shall be tested separately, to determine if the protective equipotential bonding path for that part is adequate to withstand the test current that the bonding path may be subjected to under fault conditions. The circuit under consideration shall be selected from amongst those circuits adjacent to the accessible part under consideration and separated from it by only basic or functional insulation. All of these selected circuits have to be analysed regarding prospective short circuit current and the associated protective element(s): - If the circuit under consideration exceeds the 5 s disconnection time requirement of IEC 60364-4-41, the protective equipotential bonding impedance test of 5.2.3.11.2 and the protective equipotential bonding short circuit test of 5.2.3.11.3 have to be performed. - If the circuit under consideration meets the 5 s disconnection time requirement of IEC 60364-4-41, the protective equipotential bonding short circuit test of 5.2.3.11.3 has to be performed. - If the circuit under consideration meets the disconnection time requirement of IEC 60364-4-41:2005, Table 41.1, as applicable, depending on the earthing system of the installation, no type test is required.	Considered	P
	For pluggable equipment type A only the protective equipotential bonding impedance test of 5.2.3.11.2 have to be performed.	Fixed connection	N/A
5.2.3.11.2	Protective bonding impedance test (type test)		P
5.2.3.11.2.1	Test Conditions		P
	Where required by 4.4.4.2.2 and 5.2.3.11.2.1, the impedance of protective equipotential bonding means shall be checked by passing a test current through the bond for a period of time. The test current is based on the rating of the overcurrent protection for the equipment or part of the equipment under consideration, as follows:	Considered	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	• for pluggable equipment type A, the overcurrent protective device is that provided external to the equipment (for example, in the building wiring, in the mains plug or in an equipment rack); • for pluggable equipment type B and permanently connected equipment, the maximum rating of the overcurrent protective device specified in the equipment installation instructions to be provided external to the equipment; • the rating of the provided overcurrent device for a circuit or part of the equipment for which an overcurrent protective device is provided as part of the equipment.		
5.2.3.11.2.2	Test current, duration, and acceptance criteria:		P
	a) For PECS with an overcurrent protective device rating of 16 A or less, this test may be omitted, if an impedance not exceeding 0.1 Ω can be demonstrated.		N/A
	b) As an alternative to Table 29, where the time-current characteristic of the overcurrent protective device that limits the fault current in the protective equipotential bonding means is known because the device is either provided in the equipment or fully specified in the installation instructions, the test duration may be based on that specific device's time-current characteristic. The tests are conducted for a duration corresponding to the 200 % current value on the time-current characteristic.		P
	c) For PECS with an overcurrent protective device rating of more than 460 A, calculations or simulations according to IEC 60949 shall be used to show the ability of the prospective short circuit current to fulfil the requirements. The protective equipotential bonding continuity routine test of 5.2.3.11.4 shall be performed to show that the impedance of the protective equipotential bonding means during and at the end of the test shall not exceed the expected value.		N/A
	Acceptance criteria: The test current is 200 % of the overcurrent protective device rating and the duration of the test is as shown in Table 29. The voltage drop in the protective equipotential bonding means, during and at the end of the test, shall not exceed DVC As, as determined from Table 2		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	and Table 5 with respect to the accessible surface of the enclosure.		
	After the tests, visual inspection shall show no damage to the <i>protective equipotential bonding</i> means.		P
5.2.3.11.3	Protective bonding short circuit withstand test (type test)		P
	As required by 5.2.3.11.2.1, the short circuit test in 5.2.4.3 shall be performed to ensure that protective bonding has the ability to withstand the prospective short circuit current that it may be subjected to under fault conditions.	Complied.	P
	The testing shall include an individual test of the protective bonding path for each conductive accessible part unless analysis shows that the short circuit withstand capability of the path is adequate, or that the results of one combination are representative of the anticipated results of another combination.	Complied.	P
5.2.3.11.4	Protective bonding continuity test (routine test)		P
5.2.4	Abnormal operation and simulated faults tests		P
5.2.4.1	General	See table 4.2 and 4.3	P
5.2.4.2	Pass criteria		P
	As a result of the abnormal operation tests, the PCS shall comply with the following: • there shall be no emission of flame, burning particles or molten metal; • the surgical cotton indicator shall not have ignited; • the earth connection and protective bonding of the PCS shall not have opened; • doors and cover shall remain in place; • during and after the test, accessible DVC As, SELV and PELV circuits and accessible conductive parts shall not exhibit voltages greater than the time dependent voltages of Figure 1, Figure 2 or Figure 3, as appropriate and shall be separated from live parts at voltages greater than DVC As with at least basic insulation. Compliance shall be	Fulfil requirements	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	checked by the a.c./d.c. insulation test of 5.2.3.4 for basic insulation; - during and after the test, live parts at voltages greater than DVC As shall not become accessible. - components, e.g. busbar supports, used for the mounting of live parts not break away from their initial position, (IEC 62477-1:2012/AMD1:2016) - no conductor shall get pulled out of its terminal connector. (IEC 62477-1:2012/AMD1:2016)		
	The PCS is not required to be operational after testing and it is possible that the enclosure can become deformed. Overcurrent protection integral to the PECS, or required to be used with the PECS, is allowed to open.	Fulfil requirements	P
5.2.4.3	Protective bonding short circuit withstand test (type test)		P
5.2.4.3.1	General		P
	When required by 5.2.3.11.2.1, a protective bonding path shall be subjected to the following short-circuit withstand test.	Fulfil requirements	P
5.2.4.3.2	Test conditions		P
	The equipment under test shall be supplied with power and the output port shall be operating as intended in 5.2.4.1 prior to closing the switching means that applied will be more severe.	See table 4.2 to 4.3	P
	The protective bonding short circuit test shall be performed with the PCS working with light load, unless analysis shows that higher short circuit currents are available under higher loading conditions.	See table 4.2 to 4.3	P
	A new sample may be used for each short-circuit test.		P
5.2.4.3.3	Protective equipotential bonding short-circuit test method	Considered	P
5.2.4.3.4	Pass criteria	Considered	P
5.2.4.4	Output Short-circuit test (type test)		P
5.2.4.4.1	Load conditions	100%P _n	P
	The short circuit test shall be performed with the PCS at full load or light load whichever creates the more severe condition.	See table 4.2 to 4.3	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
5.2.4.4.2	Short-circuit test method		P
	In addition to determining compliance with the criteria of 5.2.4.2, this test is used to determine the output short circuit current rating of the port under consideration, in accordance with 4.3.2.3. An oscilloscope or other suitable instrument shall be used to measure the peak current during the test, and to measure or calculate the r.m.s. value of the current.	Fulfil requirements	P
	The value(s) to be recorded and to be provided with the PECS instructions, in accordance with 6.2, are the peak current, and the highest of the r.m.s. current values measured or calculated over a time period as follows: a) for a.c. signals, three cycles of the nominal a.c. frequency for the port under consideration, in which case the value is to be stated as the 3-cycle r.m.s. value; b) for all signals, the duration of the short circuit from the time the short circuit is applied, until the time the short circuit current is interrupted by a protective device or other mechanism, in which case the value stated is to include the r.m.s. value and the time period in seconds; c) for short circuit tests that result in a continuous non-zero value, the steady-state r.m.s. value, in which case the value is to be stated as a continuous r.m.s. value. For PECS with internal short circuit protection according to 4.3.2.3, which protects the output port within some few μs, the requirements in a), b) and c) are not applicable.	Fulfil requirements	P
5.2.4.5	Output Overload test (type test)	Considered	P
5.2.4.6	Breakdown of components test (type test)		P
5.2.4.6.1	Load conditions	See table 4.2 and 4.3	P
	The breakdown of a component, identified as a result of the circuit analysis of 4.2, shall be tested with the PCS at full load or light load whichever creates the more severe condition.	Tested with the PCS at full load	P
5.2.4.6.2	Application of short-circuit or open-circuit	Short-circuit	P
	The short circuit shall be applied with cable of a cross-section appropriate for the current that normally flows through the component, but no less than 2.5 mm ² . The length of the	Fulfil requirements	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	loop shall be as short as practical to perform the test. Short circuits and open circuits are applied using an appropriate switching device.		
	Each identified component shall be subjected to only one breakdown of components test unless both open- and short-circuit failure modes are likely in that component.		P
5.2.4.6.3	Test sequence		P
	For the Breakdown of components test, identified components shall be short-circuited or open-circuited, whichever creates the worst hazard, one at a time.	Fulfil requirements	P
5.2.4.7	PWB short-circuit test (type test)		P
	On PWBs, functional insulation provided by spacings which are less than those specified in Table 10 and Table 11 (see 4.4.7.7) shall be type tested as described below.		P
	The decreased spacings shall be short-circuited one at a time, on representative samples, and the short-circuit shall be maintained until no further damage occurs.		P
5.2.4.8	Loss of phase (type test)	See table 4.2 to 4.3	P
	A multi-phase PCS shall be operated with each line (including neutral, if used) disconnected in turn at the input. The test shall be performed by disconnecting one line with the power conversion equipment operating at its maximum normal load and shall be repeated by initially energizing the device with on lead disconnected.	See table 4.2 to 4.3	P
	The test shall continue until terminated by a protective mechanism, a component failure occurs, or the temperature stabilizes.	See table 4.2 to 4.3	P
	This particular requirement may be simulated for PCS with rated input current greater than 500 A.	See table 4.2 to 4.3	P
5.2.4.9	Cooling failure tests (type test)		P
5.2.4.9.1	General and pass criteria		P
	For PCS having a combination of cooling mechanisms, all relevant tests shall be performed. It is not necessary to perform the tests simultaneously. The test shall continue, - until the temperature stabilizes, in which case the temperature limits of 4.6.4.2 apply;	See table 4.2 to 4.3	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	or - until terminated by a protective mechanism or a component failure occurs, in which case the temperature limits of 4.6.4.2 may be exceeded by not more than 5°C. If this is not possible a warning statement shall be provided in the user documentation.		
	NOTE The temperature increase of 5 °C with regard to the steady state limits reflect the spread of the burn threshold given in IEC Guide 117.		N/A
5.2.4.9.2	Inoperative blower motor	See table 4.2 to 4.3	P
	A PCS having forced ventilation shall be operated at rated load with fan or blower motor or motors made inoperative, singly or in combination from a single fault, by physically preventing their rotation.		P
5.2.4.9.3	Clogged filter	No such device	N/A
	Enclosed PCS having filtered ventilation openings shall be operated with the openings blocked to represent clogged filters. The test shall be performed initially with the ventilation openings blocked 50 %. The test shall be repeated under full blocked condition.		N/A
5.2.4.9.4	Loss of coolant	See table 4.2 to 4.3	P
	A liquid cooled PCS shall be operated at rated load. Loss of coolant shall be simulated by draining the coolant, blocking the flow or disabling the system coolant pump.		P
	If the PCS is shut down due to the operation of a thermal device located inside the coolant, then the test shall be repeated with the coolant drained out of the system.		P
	NOTE: It is presumed that the thermal device will be inoperative if not surrounded by coolant liquid.		P
5.2.4.10	Short time withstand current (I_{cw}) test (type test) (IEC 62477-1:2012/AMD1:2016)		P
5.2.4.10.1	General (IEC 62477-1:2012/AMD1:2016)		P
	As required in 4.3.5, the short time withstand current test performed as a type test to verify the safety of the PECS. (IEC 62477-1:2012/AMD1:2016)		P
	Short-circuits are applied in the PECS at locations based on the evaluation in 4.2 so that terminals and other parts in the fault current path are being exposed to the short-		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	circuit current. (IEC 62477-1:2012/AMD1:2016)		
5.2.4.10.2	Short time withstand current test method (IEC 62477-1:2012/AMD1:2016)		P
	The input mains supply port terminals provided with a cable with a cross-section as specified for the installation. (IEC 62477-1:2012/AMD1:2016)		P
	If a switching device is used to initiate the short-circuit or switch the power to the PECS, it not limit the test current. (IEC 62477-1:2012/AMD1:2016)		P
	The complete length of the cable (forth and back) approximately 2 m, unless this length is insufficient, in which case the length as short as practical to perform the test. (IEC 62477-1:2012/AMD1:2016)		P
	The testing include individual tests for each input mains supply port. (IEC 62477-1:2012/AMD1:2016)		P
	The worst case combination of terminals (including neutral and earth) subjected to a short-circuit test. (IEC 62477-1:2012/AMD1:2016)		P
	The PECS can be tested unenergized and not operating as intended prior to the short-circuit withstand test, if it can be shown that the test result is not affected. (IEC 62477-1:2012/AMD1:2016)		P
	A new sample used for each short-circuit test. (IEC 62477-1:2012/AMD1:2016)		P
	Table 37 lists the a.c. current test method as a minimum requirement for PECS. (IEC 62477-1:2012/AMD1:2016)		P
5.2.4.10.3	Compliance criteria (IEC 62477-1:2012/AMD1:2016)		P
	As a result of the short time withstand current (I_{cw}) test, the PECS comply with the compliance criteria of 5.2.4.2. (IEC 62477-1:2012/AMD1:2016)		P
5.2.5	Material tests		P
5.2.5.1	General	Metal enclosure used.	P
	When requested by 4.4.7.8.2, the manufacturer shall test the flammability properties of the materials used for insulating purposes, as defined in 5.2.5.2, 5.2.5.3 and 5.2.5.4. When requested by 4.6.3.2 the manufacturer	Metal enclosure used.	N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	shall test the flammability properties of the materials used for fire enclosure, as defined in 5.2.5.5.		
5.2.5.2	High current arcing ignition test (type test)	Metal enclosure used.	N/A
5.2.5.3	Glow-wire test (type test)	Metal enclosure used.	N/A
	The glow-wire test shall be made under the conditions specified in 4.4.7.8.2 according to IEC 60695-2-10 and IEC 60695-2-13.		N/A
5.2.5.4	Hot wire ignition test (type test – alternative to Glow-wire test)	Metal enclosure used.	N/A
5.2.5.5	Flammability test (type test)	Metal enclosure used.	N/A
5.2.5.6	Flaming oil test (type test)		N/A
5.2.5.7	Test of cemented joints (type test)	No cemented joints	N/A
	When required by 4.4.7.9 representative samples of cemented joints providing protection of type 1 or type 2 as defined in IEC 60664-3:2003 shall be tested as a type test as follows. The samples shall be subjected to the conditioning procedure specified in 5.7 of IEC 60664-3:2003, using the following parameters: for the cold test (5.7.1), a temperature of -25 °C shall be used, and for the rapid change of temperature test (5.7.3): -25 °C to +125 °C. After the conditioning the samples shall pass the following tests in the prescribed order: a) The mechanical strength of the joint shall be evaluated by loading the joint using the forces anticipated to be present under normal conditions. There shall be no separation of the parts. b) The insulation resistance between the conductive parts separated by the joint shall be measured according to 5.8.3 of IEC 60664-3:2003. c) Cemented joints shall be treated as to be thin sheet material and shall be tested according 4.4.7.8.3. d) The sectioning of the joint shall not show any cracks, voids or separation.		N/A
5.2.6	Environmental tests (type test)		P
5.2.6.1	General	Considered	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	Compliance is shown by conducting test of 5.2.6.3, 5.2.6.4, 5.2.6.5 and 5.2.6.6 according to Table 30 as applicable for the environmental conditions specified by the manufacture.	fulfil requirements	P
5.2.6.2	Acceptance criteria		P
	The following acceptance criteria shall be satisfied: - no degradation of any safety-relevant component of the PCS; - no potentially hazardous behaviour of the PCS during the test; - no sign of component overheating; - no live part shall become accessible; - no cracks in the enclosure and no damaged or loose insulators; - pass routine a.c. or d.c. voltage test 5.2.3.4; - pass protective bonding test 5.2.3.11.2; - no potentially hazardous behaviour when the PCS is operated following the test.	fulfil requirements	P
5.2.6.3	Climatic tests		P
5.2.6.3.1	Dry heat test (steady state)		P
	To prove the ability of components and equipment to be operated, transported or stored at high temperatures the dry heat (steady state) test shall be performed according to the conditions specified in Table 31.		P
5.2.6.3.2	Damp heat test (steady state)		P
	To prove the resistance to humidity, the PCS shall be subjected to a Damp heat test (steady state) according to Table 32.		P
5.2.6.4	Vibration test (type test)		N/A
	To verify the mechanical vibration strength the PECS in combination with its installation shall be evaluated by: a) tests defined in this section according to the conditions specified in Table 33; - or b) calculation or simulation based on tests, as defined in this section, on a representative model of PECS.		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	For PCS with a mass more than 100 kg, this test may be performed on sub-assemblies. NOTE For large equipment, the possibility of using a shock test as an alternative to a vibration test is under consideration.		
5.2.6.5	Salt mist (type test)		N/A
	To verify the resistance against salt mist, the PECS in combination with its installation shall be evaluated by tests defined in this section according to the conditions specified in Table 34. For PCS with a mass more than 100 kg, this test may be performed on sub-assemblies.		N/A
5.2.6.6	Dust and sand (type test)		N/A
	To verify the mechanical strength against dust and sand the PECS in combination with its installation shall be evaluated by tests defined in this section under the conditions specified in Table 35. For PCS with a mass more than 100 kg, this test may be performed on sub-assemblies.		N/A
5.2.7	Hydrostatic pressure (type test and routine test)		P
	For type tests, the pressure inside the cooling system of a liquid cooled PCS (see 4.7.2.3.3) shall be increased at a gradual rate until a pressure relief mechanism (if provided) operates, or until a pressure of twice the operating value or 1.5 times the maximum pressure rating of the system is achieved, whichever is the greater. <i>NOTE: for the purpose of this test the coolant pump may be disabled.</i> For routine tests, the pressure shall be increased to the maximum pressure rating of the system. The pressure shall be maintained for at least one minute. There shall be no thermal, shock, or other hazard resulting from the test. There shall be no significant leakage of coolant or loss of pressure during the test, other than from a pressure relief mechanism during a type test. After the hydrostatic pressure type test the PCS shall pass the a.c. or d.c. voltage test 5.2.3.4.	Twice the operating pressure value of the system is achieved	P
6	INFORMATION AND MARKING REQUIREMENTS		P
6.1	General		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
6.2	Information for selection (IEC 62477-1:2012/AMD1:2016)		P
	- the name or trademark of the manufacturer, supplier or importer;	See copy of marking plate	P
	- catalogue number or equivalent;	See copy of marking plate	P
	- electrical ratings for each power port: - maximum nominal input voltage; - maximum nominal output voltage; - maximum nominal output current or nominal output power rating; - maximum nominal input current rms for dimensioning overload protective elements and wiring; - number of phases (e.g. 3 a.c.); - nominal frequency range (e.g. 50 Hz to 60 Hz); - protective class (I, II, III);	See copy of marking plate	P
	- the type of electrical supply system (e.g. TN, IT) to which the PECS may be connected;	TN	P
	- short-circuit current rating(s) in terms of: - conditional short-circuit current (I_{cc}) and minimum required prospective short-circuit current $I_{cp, mr}$ and the characteristics of the short-circuit protective device according to clause 4.3.2.2, or - rated short time withstand current (I_{cw}), duration and the rated peak withstand current (I_{pk}) according to 4.3.5.		P
	- output short-circuit current in accordance with 4.3.2.3;		P
	- supply requirements of the load (if applicable);	Specially developed for the electrolytic hydrogen production system	P
	- liquid coolant type and design pressure for liquid cooled PECS;	Outlet pressure: rated value 2.0 bar, maximum value 2.3 bar. Static pressure: 1.5	P
	- IP rating for enclosure;	Refer to model list	P
	- operating and storage environment;		P
	- reference(s) to relevant standard(s) for manufacture, test, or use;		P
	- reference to instructions for installation, use and maintenance.		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
6.3	Information for installation and commissioning		P
6.3.1	General	Provided in the user manual	P
6.3.2	Mechanical considerations		P
	The following drawings shall be prepared by the manufacturer: - Dimensional drawing, including mass information - Mounting drawing	Fulfil requirements	P
6.3.3	Environment		P
	In accordance with 4.9 the following environmental conditions shall be specified, for operation, transportation and storage:	Fulfil requirements	P
	Climatic (temperature, humidity, altitude, pollution, ultra-violet light, etc.)	Fulfil requirements	P
	Mechanical (vibration, shock, drop, topple, etc.)	Fulfil requirements	P
	Electrical (overvoltage category)	Fulfil requirements	P
6.3.4	Handling and mounting		P
	In order to prevent injury or damage, the installation documents shall include warnings of any hazards which can be experienced during installation. Where necessary, instructions shall be provided for: - packing and unpacking; - moving; - lifting; - strength and rigidity of mounting surface; - fastening; - provision of adequate access for operation, adjustment and maintenance.	The installation documents is include warnings of any hazards	P
6.3.5	Enclosure temperature		P
	When surface temperatures of the PECS, close to mounting surfaces, exceed the limit of 4.6.4.2, the installation manual shall contain a warning to consider the combustibility of the mounting surface.	Not exceed the limit	N/A
	Where required by 4.6.3.1, the following marking shall appear on the PECS and in the installation instructions: "suitable for mounting on concrete or other non-combustible surfaces only".		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
6.3.6	Connections		P
6.3.6.1	General		P
	Information shall be provided to enable the installer to make safe electrical connection to the PCS. This shall include information for protection against hazards (for example, electric shock or availability of energy) that may be encountered during installation, operation or maintenance.	Fulfil requirements	P
6.3.6.2	Interconnection and wiring diagrams		P
	The installation and maintenance manuals shall include details of all necessary connections, together with a suggested interconnection diagram.	The user manuals include details of all necessary connections, together with a suggested interconnection diagram.	P
6.3.6.3	Conductor (cable) selection		P
	The Installation manual shall define the voltage and current levels for all connections to the PCS, together with cable insulation requirements. These shall be worst-case values, taking into account overcurrent and overload conditions and the possible effects of non-sinusoidal currents.	The user manual define the voltage and current levels for all connections to the PCS.	P
6.3.6.4	Terminal capacity and identification		P
	The installation and maintenance manuals shall indicate the range of acceptable conductor sizes and types (solid or stranded) for all terminals, and also the maximum number of conductors which can simultaneously be connected.	The user manuals indicate the range of acceptable conductor sizes and types (solid or stranded) for all terminals	P
	For field wiring terminals, the manuals shall specify the requirements for tightening torque values and also the insulation temperature rating requirements for the conductor or cable.		P
	The identification of all field wiring terminals shall be marked on the PCS, either directly or by label attached close to the terminals.	The identification of all field wiring terminals is marked on the PCS, either directly or by label attached close to the terminals.	P
	The installation and maintenance manuals identify all external terminals relating to circuits protected by one of the methods of 4.4.6.4.	Fulfil requirements	P
6.3.7	Protection requirements		P
6.3.7.1	Accessible parts circuits		P
	The installation, users and maintenance manuals shall identify any accessible parts at	The users manuals identify any accessible parts at voltages greater	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	voltages greater than DVC As, and shall describe the insulation and separation provisions required for protection.	than DVC As, and shall describe the insulation and separation provisions required for protection.	
	The manuals shall also indicate the precautions to be taken to ensure that the safety of DVC As connections maintained during installation.	The manuals also indicate the precautions to be taken to ensure that the safety of DVC As connections maintained during installation.	P
	Where a hazard is present after the removal of a cover, a warning label shall be placed on the equipment. The label shall be visible before the cover is removed.	Fulfil requirements	P
	The manual of a PCS state the maximum voltage allowed to be connected to each port.	The manual of a PCS is state the maximum voltage allowed to be connected to each port.	P
	The manuals provide instructions for the use of PELF circuits within a zone of equipotential bonding.		P
6.3.7.2	Type of electrical supply system		P
	The installation manual or the PECS specify requirements for safe earthing including the permitted earthing system of the installation (see 4.4.7.1.4)	The users manual or the PECS specify requirements for safe earthing including the permitted earthing system of the installation	P
	The unacceptable earthing systems shall be indicated as: - not permitted; or - with modification of values and/or safety levels which shall be quantified through type test.		P
6.3.7.3	Protective class		P
6.3.7.3.1	General		P
	The installation manual of the PECS shall declare the protective class specified for the PECS and the product shall be marked according to the requirement of 6.3.7.3.2, 6.3.7.3.3, and 6.3.7.3.4.	The users manual of the PECS declares the protective class specified for the PECS	P
6.3.7.3.2	Protective class I equipment		P
	Terminals for connection of the PE conductor shall be clearly and indelibly marked with one or more of the following:		P
	The symbol IEC 60417-5019 (2011-01)	 used for PE terminal	P
	With the letters PE		N/A
	The colour coding green or green-yellow		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
6.3.7.3.3	Protective class II equipment	Class I equipment	N/A
	Equipment of protective class II shall be marked with symbol IEC 60417-5172 (2011-01) (see Annex C). Where such equipment has provision for the connection of an earthing conductor for functional reasons (see 4.4.6.3) it shall be marked with symbol IEC 60417-5018 (2011-01) (see Annex C).	Class I equipment	N/A
6.3.7.3.4	Protective class III equipment	Class I equipment	N/A
	No marking is required on the product.	Class I equipment	N/A
6.3.7.4	Touch current marking		P
	Where the touch current in the PE conductor exceeds the limits given in 4.4.4.3.3., this shall be stated in the installation and maintenance manuals. In addition, a warning symbol ISO 7010- W001 (2011-06) (see Annex C) shall be placed on the product, and a notice shall be provided in the installation manual to instruct the user that the minimum size of the PE conductor shall comply with the local safety regulations for high PE conductor current equipment.	 was on rating label, and user manual indicate the minimum size of the PE conductor is 25 mm ² .	N/A
6.3.7.5	Compatibility with RCD marking	No RCD	N/A
	The installation and maintenance manuals shall indicate compatibility with RCDs (see 4.4.8). When 4.4.8 b) applies, a caution notice and the symbol ISO 7010-W001 (2011-06) (see Annex C) shall be provided in the user manual, and the symbol shall be placed on the product. The caution notice shall be the following or equivalent: "This product can cause a d.c. current in the PE conductor. Where a residual current-operated protective device (RCD) is used for protection against electrical shock, only an RCD of Type B is allowed on the supply side of this product." (See 6.4.3 for general requirements for labels, signs and signals.)		N/A
6.3.7.6	Cable and connection		P
	Any particular cable and connection requirements shall be identified in the installation and maintenance manuals.	Any particular cable and connection requirements is identified in the users manuals.	P
6.3.7.7	External protection devices	No external protection devices	N/A
	Where external devices are necessary to protect against hazards, the installation manual shall specify the required characteristics (see also 5.2.4 and 4.3.2.1)		N/A

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
6.3.8	Commissioning	No Commissioning	N/A
	If commissioning tests are necessary to ensure the electrical and thermal safety of a PCS, information to support these tests shall be provided for each part of the PCS. This information can depend on the specific installation, and close cooperation between manufacturer, installer, and user can be required. Commissioning information shall include references to hazards that might be encountered during commissioning, for example those mentioned in 6.4. and 6.5.		N/A
6.4	Information for use		P
6.4.1	General	Considered.	P
	The user's manual shall include all information regarding the safe operation of the PCS. In particular, it shall identify any hazardous materials and risks of electrical shock, overheating, misuse of the PCS.	The user manual is include all information regarding the safe operation of the PCS.	P
	The manual should also indicate any hazards which can result from reasonably foreseeable misuse of the PCS.		P
6.4.2	Adjustment	Considered.	P
	The user's manual shall give details of all safety-relevant adjustments intended for the user. The identification or function of each control or indicating device and fuse shall be marked adjacent to the item. Where it is not possible to do this on the product, the information shall be provided pictorially in the manual.	Fulfil requirements	P
	Maintenance adjustments may also be described in this manual, but shall be made clear that they should only be made by qualified personnel.	Fulfil requirements	P
	Clear warnings shall be provided where excessive adjustment could lead to a hazardous state of the PCS.	Fulfil requirements	P
	Any special equipment necessary for making adjustments shall be specified and described.	Fulfil requirements	P
6.4.3	Labels, signs and signals		P
6.4.3.1	General		P
	Labelling shall be in accordance with good ergonomic principles so that notices, controls, indications, test facilities, fuses, etc., are sensibly placed and logically grouped to	Considered.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	facilitate correct and unambiguous identification. All safety related equipment labels shall be located so as to be visible after installation or readily visible by opening a door or removing a cover. Where a symbol is used, the information provided with the PCS shall contain an explanation of the symbol and its meaning.		
	Labels shall: • wherever possible, use international symbols as given by ISO 3864-1, ISO 7000 or IEC 60417; • if no international symbol is available, be worded in an appropriate language or in a language associated with a particular technical field; • be concise and unambiguous; • be conspicuous, legible and durable; • state the hazards involved and give ways in which risks can be reduced.	Considered.	P
	When instructing the person(s) concerned as to • what to avoid: the wording should include “no”, “do not”, or “prohibited”; • what to do: the wording should include “shall”, or “must”; • the nature of the hazard: the wording should include “caution”, “warning”, or “danger”, as appropriate; • the nature of safe conditions: the wording should include the noun appropriate to the safety device.	Considered.	P
	Safety signs shall comply with ISO 3864-1.		P
	The signal words indicated hereinafter shall be used and the following hierarchy respected: • DANGER to call attention to a high risk, for example: “High voltage”. • WARNING to call attention to a medium risk, for example: “This surface can be hot.” • CAUTION to call attention to a low risk, for example: “Some of the tests specified in this standard involve the use of processes imposing risks on persons concerned.” Danger, warning and caution markings on the PECS shall be prefixed with the word “DANGER”, “WARNING”, or “CAUTION” as appropriate in letters not less than 3.2 mm	Considered.	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	high. The remaining letters of such markings shall be not less than 1.6 mm high.		
6.4.3.2	Isolators	No such Isolators	N/A
	Where an isolating device is not intended to interrupt load current, a warning shall state: DO NOT OPEN UNDER LOAD.	No such Isolators	N/A
	The following requirements apply to any supply isolating device which does not disconnect all sources of power to the PCS.	No such Isolators	N/A
	If the isolating device is mounted in an equipment enclosure with the operating handle externally operable, a warning label shall be provided adjacent to the operating handle stating that it does not disconnect all power to the PCS.	No such Isolators	N/A
	Where a control circuit disconnecter can be confused with power circuit disconnectors due to size or location, a warning label shall be provided adjacent to the operating handle of the control disconnecter stating that it does not disconnect all power to the PCS.	No such Isolators	N/A
6.4.3.3	Visual and audible signals	Considered	P
	Visual signals such as flashing lights, and audible signals such as sirens, may be used to warn of an impending hazardous event such as the driven equipment start-up and shall be identified. It is essential that these signals: - are unambiguous; - can be clearly perceived and differentiated from all other signals used; - can be clearly recognized by the user; - are emitted before the occurrence of the hazardous event. It is recommended that higher frequency flashing lights be used for information. Note: IEC 60073 provides guidance on recommended flashing rates and on/off ratios.	Fulfil requirements	P
6.4.3.4	Hot surfaces	No such surface.	N/A
	Where required by 4.6.4.2 the warning symbol W017 of ISO 7010 shall be marked on or adjacent to parts exceeding the touch temperature limits of Table 15.		N/A
6.4.3.5	Equipment marking		P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	The Identification of each control or indicating device and fuse shall be marked adjacent to the item. Replaceable fuses shall be marked with their rating and time characteristics. Where it is not possible to do this on the product, the information shall be provided pictorially in the manual. Appropriate identification shall be marked on or adjacent to each movable connector. Test points shall be individually marked with the circuit diagram reference. The polarity of any polarized devices shall be marked adjacent to the device. The diagram reference and if possible the function shall be marked adjacent to each pre-set control in a position where it is clearly visible while the adjustment is being made.	Fuses used and not located in operator access areas. The fuse information contains in the users manual.	P
6.5	Information for maintenance		P
6.5.1	General	All below related information provided in the users manual.	P
	The PECS shall be marked with the date code, or serial number from which the date of manufacture can be determined.	Fulfil requirements	P
	Safety information shall be provided in the installation and maintenance manuals including appropriate, the following:	Fulfil requirements	P
	• Preventive maintenance procedures and schedules	Fulfil requirements	P
	• Safety precautions during maintenance	Fulfil requirements	P
	• Location of live parts that can be accessible during maintenance (for example, when covers are removed)	Fulfil requirements	P
	• Adjustment procedures	Fulfil requirements	P
	• Subassembly and component repair and replacement procedures	Fulfil requirements	P
	• Any other relevant information	Fulfil requirements	P
6.5.2	Capacitor discharge		P
	When the requirements 4.4.9 are not met, the warning symbol W012 of ISO 7010 and an indication of the discharge time (for example, 45 s, 5 min) shall be placed in a clearly visible position on the enclosure, the capacitor protective barrier, or at a point close to the capacitor(s) concerned (depending on the construction). The symbol shall be explained and the time required for the capacitors to	Symbol and an indication of the discharge time used in a clearly visible position	P

IEC 62477-1			
Clause	Requirement – Test	Measuring result – Remark	Verdict
	discharge after the removal or the power from the PCS shall be stated in the installation and maintenance manuals.		
6.5.3	Auto restart/bypass connection		N/A
	If a PCS can be configured to provide automatic restart or bypass connection, the installation, user and maintenance manuals shall contain appropriate warning statements.	The PCS cannot automatically restart or bypass connection, should restart by manually	N/A
	A PCS which is set to provide automatic restart or bypass connection, after the removal of power, shall be clearly identified at the installation.		N/A
6.5.4	Other hazards	Considered.	P
	The manufacturer shall identify any components and materials of a PCS which require special procedures to prevent hazards.		P
6.5.5	Equipment with multiple sources of supply		P
	In accordance with 4.8, where there is more than one source of supply energizing the PCS, information shall be provided to indicate which disconnect device or devices are required to be operated in order to completely isolate the equipment.	 used and related information specified.	P

4	TABLE: mains supply electrical data in normal condition						P
Type	DC			AC			
	U (Vac)	I (Aac)	P (W)	U (Vdc)	I (Adc)	P (W)	
JSLES-241L120							
Discharge / Grid Mode	799.72	152.96	122148.38	207.83	191.00	118895.85	
	799.71	153.33	122500.60	230.11	173.61	119712.98	
	799.72	152.71	122045.78	252.88	157.85	119629.49	
Charge Mode	800.62	145.16	115983.61	207.78	191.67	119189.52	
	800.62	146.45	117096.32	229.79	174.02	119828.06	
	800.61	146.72	117357.23	252.79	158.00	119713.37	
JSLES-241L80							
Discharge / Grid Mode	799.88	101.78	81277.22	207.87	127.56	79423.03	
	799.87	101.64	81199.82	230.06	115.49	79577.49	
	799.88	102.00	81513.38	252.84	105.75	80073.19	
Charge Mode	800.45	97.35	77735.75	207.83	127.82	79559.57	
	800.45	98.27	78518.83	229.83	116.39	80119.55	
	800.45	98.17	78474.01	252.84	105.49	79885.74	
JSLES-241L60							
Discharge / Grid Mode	799.95	75.82	60530.72	207.84	95.19	59216.76	
	799.95	76.54	61131.63	230.03	87.11	59979.04	
	799.95	75.99	60710.71	252.82	78.95	59743.11	
Charge Mode	800.38	73.03	58299.20	207.86	95.82	59593.80	
	800.50	73.05	58353.60	229.89	86.44	59472.85	
	800.38	73.95	59084.83	252.86	79.32	60035.42	

4.2 to 4.3		TABLE: fault condition tests					P
		test voltage (V)		See below		—	
		Ambient temperature (°C)		25°C, if not stated otherwise			
No.	component No.	fault	test voltage (V)	test time	fuse No.	fuse current	result
Whole System							
1.	Sensor Temperature and alarm power supply	S-C	768Vdc 230Vac	10min	-	-	The System shut down. No hazard, no damage, no fire
2.	Liquid cooling system power supply	O-C	768Vdc 230Vac	10min	-	-	The System shut down. No hazard, no damage, no fire
3.	Liquid cooling system	leakage	768Vdc 230Vac	10min	-	-	Low pressure of the cooling unit. The System shut down. No hazard, no damage, no fire
Battery Module							
4.	MCU(U6) on main board PIN 32 to VCC	S-C	768Vdc 230Vac	10min	-	-	The power relay switched off. Cease to output. No hazard, no damage, no fire
5.	MCU(U8) on slave board PIN 1 to VCC	S-C	768Vdc 230Vac	10min	-	-	The power relay switched off. Cease to output. No hazard, no damage, no fire
6.	AFE(U4) on slave board PIN11 to PIN12	S-C	768Vdc 230Vac	10min	-	-	Cell voltage cannot be read correctly. Cease to output. No hazard, no damage, no fire
7.	Cell voltage sampling line	O-C	768Vdc 230Vac	10min	-	-	Cell voltage cannot be read correctly. Cease to output. No hazard, no damage, no fire
8.	CAN (UN3) on main board PIN	O-C	768Vdc 230Vac	10min	-	-	Communication time out. The power contact switched off. No hazard, no damage, no fire
9.	CAN (U20) on main board PIN1 to PIN2	S-C	768Vdc 230Vac	10min	-	-	Communication time out. The power contact switched off. No hazard, no damage, no fire
PCS							
10.	GFCI circuit, R462	S-C	768Vdc 230Vac	10min	-	-	The PCE shut down. No hazard, no damage, no fire

11.	GFCI circuit, R490	S-C	768Vdc 230Vac	10min	-	-	The PCE shut down. No hazard, no damage, no fire
12.	Bus voltage sampling circuit, R225	O-C	768Vdc 230Vac	10min	-	-	Error code 1, Vbus error The PCE shut down. No hazard, no damage, no fire
13.	Bus voltage sampling circuit, R235	S-C	768Vdc 230Vac	10min	-	-	Error code 1, Vbus error The PCE shut down. No hazard, no damage, no fire
14.	BAT voltage sampling circuit, R179	O-C	768Vdc 230Vac	10min	-	-	Error code 2, Vbat low The PCE shut down. No hazard, no damage, no fire
15.	BAT voltage sampling circuit, R188	S-C	768Vdc 230Vac	10min	-	-	Error code 2, Vbat low The PCE shut down. No hazard, no damage, no fire
16.	Grid voltage sampling circuit, R270	O-C	768Vdc 230Vac	10min	-	-	Error code 4, Vgrid low The PCE shut down. No hazard, no damage, no fire
17.	Grid voltage sampling circuit, R253	S-C	768Vdc 230Vac	10min	-	-	Error code 4, Vgrid low The PCE shut down. No hazard, no damage, no fire
18.	Grid voltage sampling circuit, R254	O-C	768Vdc 230Vac	10min	-	-	Error code 4, Vgrid low The PCE shut down. No hazard, no damage, no fire
19.	AC Relay K5, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire
20.	AC Relay K6, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire
21.	AC Relay K3, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire
22.	AC Relay K4, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire
23.	AC Relay K1, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire

24.	AC Relay K2, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire
25.	AC Relay K7, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire
26.	AC Relay K5, signal pin	S-C	768Vdc 230Vac	10min	-	-	Error code 256, Relay Fault The PCE can not start up. No hazard, no damage, no fire
27.	Fan	Blocked	768Vdc 230Vac	30min	-	-	Error code: 16, Fan fault. The PCE shut down. No hazard, no damage, no fire, can resettable.
28.	DC input	RE	768Vdc 230Vac	10min	-	-	Error code: 32, Bat reserved. The PCE shut down. No hazard, no damage, no fire, can resettable.
29.	120% AC output	OL	768Vdc 230Vac	10min	-	-	Error code: 64, Overload The PCE shut down. No hazard, no damage, no fire, can resettable.
30.	AC terminal – PhaseA	MIS	768Vdc 230Vac	10min	-	-	Error code: 512, Phase error The PCE shut down. No hazard, no damage, no fire, can resettable.
31.	DC terminal, current overload 110%	OL	768Vdc 230Vac	10min	-	-	Error code: 8, DC over-current The PCE shut down. No hazard, no damage, no fire, can resettable.
32.	BUS circuit voltage overload	OL	768Vdc 230Vac	10min	-	-	Error code: 1024, BUS over-voltage The PCE shut down. No hazard, no damage, no fire, can resettable.
33.	INV circuit voltage overload	OL	768Vdc 230Vac	10min	-	-	Error code: 128, INV over-current The PCE shut down. No hazard, no damage, no fire, can resettable.
34.	Grid current sampling circuit, R502	O-C	768Vdc 230Vac	10min	-	-	Error code 6, Grid overcurrent The PCE shut down. No hazard, no damage, no fire,

35.	Grid current sampling circuit, R503	S-C	768Vdc 230Vac	10min	-	-	Error code 6, Grid overcurrent The PCE shut down. No hazard, no damage, no fire,
36.	Grid current sampling circuit, R504	O-C	768Vdc 230Vac	10min	-	-	Error code 6, Grid overcurrent The PCE shut down. No hazard, no damage, no fire,
37.	Master MCU, U1	O-C	768Vdc 230Vac	10min	-	-	Error code 12, SPI error The PCE shut down. No hazard, no damage, no fire,
38.	Slave MCU, U2	S-C	768Vdc 230Vac	10min	-	-	Error code 12, SPI error The PCE shut down. No hazard, no damage, no fire,
39.	IGBT, P14	S-C	768Vdc 230Vac	10min	-	-	Error code: 24, IGBT Error The PCE shut down. No hazard, no damage, no fire,
40.	IGBT detection circuit, R487	S-C	768Vdc 230Vac	10min	-	-	Error code: 24, IGBT Error The PCE shut down. No hazard, no damage, no fire,
41.	Driver detection circuit, R565	S-C	768Vdc 230Vac	10min	-	-	Error code: 36, Dirver Error The PCE shut down. No hazard, no damage, no fire,
42.	Communica tion detection circuit, R95	S-C	768Vdc 230Vac	10min	-	-	Error code: 48, COM Error The PCE shut down. No hazard, no damage, no fire,
43.	AC output	S-C	768Vdc 230Vac	10min	-	-	Error code: 128, INV over-current The PCE shut down. No hazard, no damage, no fire,
44.	GFCI circuit, R462	S-C	768Vdc 230Vac	10min	-	-	The PCE shut down. No hazard, no damage, no fire
Legend							
S-C		short-circuited			O-C		open-circuited
OL		Over-load.			MIS		Miss wiring
RE		Reverse polarity			OL		Over loaded
LP		Loss of phase			-		-
Note(s): The electric strength test performed after fault condition test and see appended table 4.4.7.10 for detailed test conditions.							

4.6.4		TABLE: heating temperature rise measurements							P
Test Condition:	Test 1	Discharge: DC self-adjustment, AC 207Vac, operated at 45°C at its maximum output power							
	Test 2	Charge Mode: AC 207Vac, DC self-adjustment, operated at 45°C at its maximum output power							
	Test 3	Discharge: DC self-adjustment, AC 207Vac, operated at 50°C(derated) at its maximum output power							
	Test 4	Charge Mode: AC 207Vac, DC self-adjustment, operated at 50°C(derated) at its maximum output power							
	Test 5	Charge – Discharge two cycle mode: AC 230Vac, DC self-adjustment, operated at 45°C at its maximum output power							
	Test 6	Cooling system do not operation: AC 230Vac, DC self-adjustment, operated at 45°C at its maximum output power							
Test Point:			Test Condition:						allowed T _{max} (°C)
			Test 1	Test 2	Test 3	Test 4	Test 5	Test 6	
General									
1.	Ambient		45.1	45.2	50.3	50.0	45.2	45.1	-
2.	Emergency switch cover plate		49.5	49.7	54.4	53.0	49.4	51.7	60.0
3.	Fire sprinkler		51.3	51.1	53.5	53.5	50.7	52.7	54.0
4.	Doorknob		48.8	49.0	54.1	52.5	48.6	51.1	70.0
5.	Indicator light		52.5	52.5	56.9	55.2	52.3	54.5	70.0
6.	Heat sink		46.5	46.6	52.1	50.1	46.4	49.0	70.0
7.	Embedded Industry Computer		58.9	59.0	59.5	59.6	59.1	59.4	60.0
8.	Front-Enclosure		51.9	51.9	55.4	54.7	51.3	53.9	70.0
9.	Communication port		66.4	65.7	67.0	67.2	65.0	66.7	70.0
10.	EMS-Enclosure		58.5	58.2	60.8	60.7	57.4	60.3	70.0
11.	BMS-Enclosure		64.2	63.2	68.1	68.2	61.7	67.2	70.0
12.	BAT+ Terminal		61.4	59.9	63.8	64.0	58.9	63.2	125.0
13.	BAT- Terminal		62.0	62.2	66.9	66.5	61.2	65.3	125.0
14.	Intelligent Dehumidifier		53.8	53.4	54.1	54.5	53.0	53.8	55.0
15.	BAT Communication port		55.8	55.3	58.7	58.0	54.3	57.7	85.0
PCS									
16.	Front-Enclosure-PCS		69.2	67.0	69.3	60.2	66.9	67.8	70.0
17.	AC Terminal-PCS		63.2	61.9	65.1	64.5	61.7	63.5	70.0
18.	heat sink-Cooling system		53.4	51.8	57.2	55.7	52.1	54.0	70.0
19.	heat sink-PCS		65.3	62.9	67.1	65.0	62.5	63.5	70.0
HV box									
20.	Enclosure		65.7	65.1	65.4	65.1	64.5	65.3	70.0
21.	Outside DC terminal		55.7	55.1	54.3	52.5	54.5	59.6	125.0

22.	Inside DC terminal	63.3	63.1	60.4	58.1	65.6	70.7	125.0
23.	AC-DC Power Converter	65.7	64.7	64.2	61.8	66.9	69.1	70.0
24.	DC-DC Power Converter	64.8	63.8	63.0	60.5	66.0	69.2	70.0
25.	DC Switch	66.3	63.6	62.7	59.8	66.7	66.3	70.0
26.	Fuse	66.0	64.3	62.8	60.1	67.1	72.6	85.0
27.	Relay	65.4	64.1	62.9	60.3	66.8	72.1	85.0
28.	Switch handle	50.3	50.0	53.1	51.5	51.6	54.6	70.0
29.	Hall sensor	64.5	63.3	62.3	59.6	65.8	70.9	125.0
30.	Fan	63.9	62.8	61.7	59.1	65.2	69.3	70.0
31.	Button(ON/OFF)	56.6	55.4	56.2	54.4	57.3	61.9	70.0
BMS								
32.	Transformer for BMU (TJ1)	68.7	67.8	71.3	70.9	71.0	62.9	125.0
33.	MCU for BCU for BMU (U6)	71.7	71.0	74.0	73.6	74.0	65.9	85.0
34.	Optocoupler for BCU (UH1)	64.6	64.0	67.6	67.4	67.1	59.6	85.0
35.	Connector for BCU(J3)	63.2	62.7	66.5	66.2	65.7	58.7	105.0
Power Box								
36.	Molded case circuit breaker	63.2	64.0	65.2	66.8	62.7	66.8	75.0
37.	Three-Phase Electric Meter	56.1	56.7	60.6	59.7	55.7	59.2	99.0
38.	AC power line	52.4	52.8	56.7	56.2	52.4	55.3	105.0
39.	PCS power line	57.5	58.7	59.0	60.9	59.8	60.9	105.0
40.	AC Terminal	64.6	63.3	75.5	74.2	62.7	70.1	120.0
41.	PCS Terminal	57.3	57.0	60.1	61.3	57.0	60.1	120.0
Battery pack								
42.	Enclosure	60.2	58.6	62.6	60.8	53.9	61.5	70.0
43.	Inside DC terminal	64.9	64.9	62.6	60.9	60.9	69.0	125.0
44.	Outside DC terminal	58.4	57.5	58.3	56.6	58.1	64.5	125.0
45.	Insulation sheet	69.0	68.2	72.0	70.3	57.6	65.8	80.0
46.	DC+ wiring	56.7	54.7	63.1	61.2	55.0	60.8	125.0
Cooling system								
47.	Front-Enclosure	59.0	59.3	59.4	61.0	59.0	60.9	70.0
48.	Communication port	58.9	58.9	58.3	60.0	58.6	60.2	70.0
49.	Intake pipe	49.0	49.2	52.7	51.7	49.3	48.1	70.0
50.	Outlet pipe	51.5	52.2	55.7	54.6	51.2	48.8	70.0
51.	Heat sink	53.4	51.8	57.2	55.7	52.1	54.0	70.0
Remark:								

4.4.7.4 to 4.4.7.5	TABLE: clearance and creepage distance measurements					P
clearance cl and creepage distance dcr at/of:	System / Impulse voltage (Vd.c.)	U r.m.s. (V)	Required cl (mm)	cl (mm)	required dcr (mm)	dcr (mm)
HV Control Box						
B+ terminal to enclosure (BI)	4000	230	3.9	29.0	4.4	29.0
B- terminal to enclosure (BI)	4000	230	3.9	39.0	4.4	39.0
B+ terminal to B- terminal (RI)	6000	230	7.1	25.0	8.8	25.0
BAT						
P+ to P-(FI)	4000	230	3.9	25.0	4.4	25.0
P+ to enclosure (BI)	4000	230	3.9	29.0	4.4	29.0
P+ to Com (RI)	6000	230	7.1	25.0	8.8	25.0
BMS						
B+ terminal to B- terminal (RI)	6000	230	7.1	16.7	8.8	16.7
Sampling Voltage + to - (RI)	6000	230	7.1	16.8	8.8	16.8
B+ to SELVE (RI)	6000	230	7.1	17.3	8.8	17.3
Transformer primary to second (RI)	6000	230	7.1	32.8	8.8	32.8
PCS- Busbar capacitor board						
B+ to PE(BI)	4000	230	3.9	11.2	4.4	11.2
B- to PE(BI)	4000	230	3.9	11.2	4.4	11.2
PCS- Module board						
B+ to PE(BI)	4000	230	3.9	11.2	4.4	11.2
B- to PE(BI)	4000	230	3.9	11.2	4.4	11.2
PCS - EMC board						
L to PE(BI)	4000	230	3.9	12.8	4.4	12.8
B- to PE(BI)	4000	230	3.9	11.7	4.4	11.7
B+ to PE(BI)	4000	230	3.9	13.2	4.4	13.2
PCS - SPS board						
Opto-coupler (BI)	4000	230	3.9	9.0	4.4	9.0
Y capacitor (BI)	4000	230	3.9	12.0	4.4	12.0
transformer (BI)	4000	230	3.9	30.0	4.4	30.0
PCS - Others						
DC to com (RI)	6000	230	7.1	47.0	8.8	47.0
AC to com (RI)	6000	230	7.1	16.0	8.8	16.0

Note(s): FI=functional insulation, BI=basic insulation, SI=supplementary insulation, RI=reinforced insulation, DI=double insulation

When determine the clearance:

For DC input circuits: Overvoltage Category II applied

For AC output circuits (connected to AC mains): Overvoltage Category III applied

Interpolation is used, operating altitude is 4000m (1.29 factor)

For the inner layer of the PCB, pollution I was considered.

Requirement about creepage distances for the distance to the metal enclosure come from columns 7 and 8 of Table 11. Requirement about creepage distances for other parts come from column 3 of table 11.

4.4.7.8.3.2 to 4.4.7.9	TABLE: distance through insulation measurement				P
distance through insulation di at/of:	U r.m.s. (V)	test voltage (V)	required di (mm)	di (mm)	
Y cap (BI)	230Vac, 768Vdc	2120Vdc	certified	certified	
Transformer (BI)	230Vac, 768Vdc	2120Vdc	certified	certified	
Opto-coupler (BI)	230Vac, 768Vdc	2120Vdc	certified	certified	
supplementary information:					

4.4.7.10	TABLE: electric strength measurements, impulse voltage test and partial discharge test				P
test voltage applied between:	test voltage (V)	impulse withstand voltage (V)	partial discharge extinction voltage (V)	result	
AC to PE	2120Vdc	4000	--	Pass	
DC to PE	2120Vdc	4000	--	Pass	
AC to DC	2120Vdc	4000	--	Pass	
AC to Comm	4240Vdc	6000	--	Pass	
DC to Comm	4240Vdc	6000	--	Pass	
Note(s):					

List of critical materials and components:

Object	Manufacturer	Type / model	Technical Data	Standard(s)	Remark
Key Components for Outdoor Energy Storage System JSLES-241L120, JSLES-241L80, JSLES-241L60 Manufacturer: Yixing JS Solar Co., Ltd.					
Enclosure of System	Nanjing Yuesheng Precision Machinery Co., Ltd	ZJJX-LES-241L120(V2.1)	Outdoor type 1000×1330×2350 Material: galvanized sheet Thickness: 2mm	IEC 62477-1 EN 62477-1	Tested with apparatus
Aerosol-Generating Extinguisher	Hubei Jiandun Fire Technology Co., Ltd	JAD300-U01	5m ³ Φ76×192mm -40 °C -+54 °C	BS EN 15276-1:2019	BSI: KM 781135
Smoke Detector	Apollo Fire Detectors Limited Ltd	55000-316	100 mm diameter x 42 mm height (50 mm high with mounting base) -20 °C - + 60 °C	EN 54-7:2018	LPCB: 010q/11
Heat Detector	Hubei Jiandun Fire Technology Co., Ltd	55000-121	100 mm diameter x 42 mm height -20 °C - + 50°C	EN54-5:2000+A1:2002	LPCB: 010q /05
Emergency Stop Switch	IEDC CORP	HW1B-V411R	-25 °C to +60°C (no fireezing) 24V 10A	UL 508, 18th Ed.	UL E68961
Air-cooled Chiller	ShenzhenEnvicool Technology Co., Ltd.	EMW50HFN C1A	refrigerating capacity@L35/W18:5K W heating capacity@Tu=10 °C:2KW Overall dimensions (H x W x D): 245×700×900mm Weight (without refrigerant):85KG -40°C ~+70°C	EN 62233:2008	TUV AM 50632900 0001
PCS	Golen Power Technology Co., Ltd.	LEG-135K-TL-P	DC:650-950V, AC:230/400V, 3/N/PE, 50Hz, Rated power: 135kW, IP 20, -30 °C ~55 °C	IEC 62477-1 EN 62477-1	TUV 44799254 06749-041

Alarm Warning Devices	Hosiden Besson Limited	Banshee ExcelLite	Operating Voltage(V dc):9-30 Flash Current Consumption(mA):40(CHX),16(CHL) IP54 -15°C- +40 °C(CHX) -20 °C- +70 °C(CHL)	EN 54-3:2001 +A1:2002 +A2:2006	LPCB: 539c
Intelligent Dehumidifier	Andes (Zhejiang) Energy Technology Co LTD	ADSBD-500ML	-30 °C~+55 °C DC24V±10% 2.5A	UL 60335-1, 6th Ed	UL-US-2414393-0
Three-Phase Electric Meter	Acrel Co., Ltd.	DTSD1352-2CF	Reference voltage: 3*100V, 3*380V, 3*57.7/100V, 3*220/380V Power consumption: <10VA (single) Impedance: >2MΩ Accuracy class: Error ±0.2% Input current:3*1(6)A, 3*1(6)A(Transformer external), 3*10 (80) A, 3*10 (100) A (transformer external) Power consumption: <1VA(single-channel rated current) Accuracy class: Error ±0.2% active power, reactive power, apparent power, error ±0.5% grid frequency: 45 ~ 65Hz, error ±0.2% 5, power: active power (accuracy level 0.5S) Reactive power (accuracy level 2)	EN 61010-1:2010+A1:2019, EN IEC 61326-1:2021	UDEM: M.2022.20 6.C72763
Current Transformers	Acrel Co., Ltd.	AKH-0.66/K-Ø24	300/5, 2000A/1A 50/60H z 0.66KV -30 °C -+70 °C	EN 61010-1:2019+A1:2019	Anbotech: AT78251S C205023

Embedded Industry Computer	SIEMENS AG	KPT 700 Basic DP	230 mA DC +24 V -20-60 °C	UL508	UL E116536
Battery Pack	Golen power technology co., Ltd	LEH015303 14C19AV01	410.4~518.4Vd.c.,314 Ah, 144.69kWh,Class I, Charge/discharge Temperature: 5°C to 55°C/-15°C to 55°C	IEC 62477-1 EN 62477-1	TUV 44799254 06749-057
Battery Pack type LEH01530314C19AV01 for Battery System					
Manufacturer: Golen power technology co., Ltd					
Cell (48 cells provided)	Xiamen Hithium Energy Storage Technology Co., Ltd.	LFP7117320 7/314Ah	3.2V, 314Ah, 1004.8Wh	IEC 62619:2022	Certificate No.:JPTU V-152897 Test report NO.: JPTUV-152897
Enclosure of Battery Pack	Anhui FineMg Technology Co., Ltd.	48S battery box	Lower box: AISi10MnMg Upper box cover: DC06 Liquid cooled plate: Al6061 Water connector: Al6061	EN 62477-1:2012+A1:2017	Tested with apparatus
NTC Resistor for cell (One Module contain 26 pcs)	MURATA	NCU18XH1 03F6SRB	R25 =10KΩ±1% B25/85=3434K±1% Temperature: -40°C to +125°C	UL1434	UL E137188 (2023-10-30)
MSD	JONHON OPTRONIC TECHNOLOGY CO., LTD.	Plug: DLQ4B-T Socket: DLQ4B-Z-B	Rated voltage: 1500 V DC Rated current: 350A Temperature: -40°C to +125°C	UL 1977:2016 R8.19	TÜV Rheinland AK 50548173 0001
Insulation sheet	Chengdu Kanglongxin Plastics Co., Ltd	KLX FRPC-1860B	Flammability: V-0 Temperature: +80°C	UL 746B	UL E315185 (2012-03-08)

Sealing ring	Suzhou Hanming Electronic Materials Co., Ltd.	H050	working temperature: -55°C to +150°C V-0	UL94 IEC 60695-11-10 UL746A UL746B	UL E537334 (2023-12-28)
DC Connector Socket(B+B-)	JONHON OPTRONIC TECHNOLOGY CO., LTD	ICG-A08BKFJ28 RY-50 ICG-A08OGFJ28 RY-50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD Z2 113817 0002 Rev.03
DC Connector Plug(B+B-)	JONHON OPTRONIC TECHNOLOGY CO., LTD	ICG-A08OGTK0 S-50 ICG-A08BKT0R -50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD Z2 113817 0002 Rev.03
Main Busbar	Suzhou PNY Precision Technology CO., LTD.	T2	Rated current: DC 250A Thickness: 2mm	EN 62477-1:2012+A1:2017	Tested with apparatus
-Main Busbar Insulating sleeve	WUJIANG TUOYAN CO.,LTD	TY-HFT-600	Thickness:0.7mm, Flammability: V0 125°C	UL224	UL E479329 (2024-02-01)
Internal wiring (signal)	ChangshuJHoSiN Communication Technology co., Ltd.	UL2517	Temperature: 105°C RATED VOLTAGE: 300V	UL 758	UL E497461 (2018-04-24)
Internal wiring (Temperature)	JIANGYIN HAOCHENG ELECTRIC APPLIANCE WIRE & CABLE MFG CO LTD	UL10588	Temperature: +200°C RATED VOLTAGE: 600V	UL 758 CSA C22.2 No. 210	UL E227587 (2012-04-11)
Anti-Explosion Valve	Huizhou Voir Science&Technology Co.,Ltd	VE-M582F-00-111	Pressure: 6±1.5Kpa Temperature: -40°C to +125°C	EN 62477-1:2012+A1:2017	Tested with apparatus
FUSE	Xi'an Sinofuse Electric Co., Ltd.	RS5C183	Rated Voltage: DC 250V Rated Current: DC 250 to 630A Temperature: -40°C to + 85°C Breaking Capacity: 50 kA	EN 60269-4:2009+A1+A2	TÜV Rheinland No.R5060 8448 0001
BMU Model BMU-B30-64-504					

BMU	HANGZHOU XIENENG TECHNOLOGY CO., LTD	Model: BMU-B30-64-504 (Hardware version:V1.4)	Monitoring the cells' temperature and voltage	EN 62477-1:2012+A1:2017	Tested with apparatus
-PCB material	SHANGHAI GLOBAL ELECTRONIC MATERIAL LTD	GF11_T6	CTI:>600 Flame level: V-0 Thickness: 0.63-1.4mm	UL94 UL746	UL E224772 (2014-06-25)
- IC for AFE (U4)	ADI	ADES1831CCSZ	Working voltage: 11V to 80V Working temperature: -40°C to +105°C	EN 62477-1:2012+A1:2017	Tested with apparatus
-Connector (JV1)	LOTES CO LTD	AAUS05AP5-016K02	Working temperature: -40°C to +85°C V-0	UL1977	UL E187055 (2024-12-06)
-Transformer (TJ1,TJ2)	Huizhou Youte Electronics Co., Ltd	UTA06C02	Working voltage: 1500V Working temperature: -40°C to +150°C	UL62368-1	UL E530055 (2024-12-06)
	Dongguan Jianxu Electronics Co., Ltd	TM0612SR	Working voltage: 1500V Working temperature: -40°C to +125°C	UL62368-1	UL E537506 (2024-12-06)
-BMS shell	FORMOSA CHEMICALS & FIBRE CORP PLASTICS DIV	PC/ABS AC310(+)	CTI:0 Flame level: V-0 Thickness: 2.3mm	UL94 UL746A UL746B	UL E162823 (2025-02-27)
HV box type LBC-HL-2 for Battery System type 1) LEH-4608-L3, 2) LEH-6144-L4, 3) LEH-7680-L5 Manufacturer: Golen Power Technology Co., Ltd.					
Enclosure of HV box	Hangzhou Kaibenite Technology Co., LTD	XN1338-0076/PDU-E15-C250-301W/Metal Plate	Material: SPCC Thickness: 2mm	EN 62477-1:2012+A1:2017	Tested with apparatus
DC Connector (socket P+P-B+B-)	JONHON OPTRONIC TECHNOLOGY CO., LTD	ICG-A08BKFJ28 RY-50 ICG-A08OGFJ28 SX-50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD No.Z2 113817 0002 Rev.03
DC Connector (plug P+P-B+B-)	JONHON OPTRONIC TECHNOLOGY CO., LTD	ICG-A08BKT0R-50 ICG-A08OGTK0S-50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD No.Z2 113817 0002 Rev.03
Precharge resistor	Anhui Kebi Electronic Technology Co.,Ltd	RXLG-200W-50R J	200W 50Ω Temperature: -55°C to +275°C	EN 60204-1:2018	UDEM CE: E2021NB0 17JS-MD

AC-DC converter	ATAZ Guangzhou Science&Technology Co.,Ltd.	AM200-B24	24V/8.8A Temperature: -40°C to +70°C	UL 62368-1	UL E2436674 (2025-01-03)
DC-DC converter	ATAZ Guangzhou Science&Technology Co.,Ltd.	HV200-15DB24	24V/8.333A Temperature: -40°C to +70°C	UL 1741	UL E541908 (2024-12-06)
Hall Sensor	LEM	DHAB S/124	Measuring range:±500A Temperature: -40°C to +125°C	UL 508	ULE189713 (2019-09-25)
Fan	TINGXIANG ELECTRIC (SHANGHAI) CO LTD	TX8025D24 B	24V 0.8A Temperature: -40°C to +70°C	UL 507	UL E526072 (2024-12-30)
Fuse	Xi'an Sinofuse Electric Co., Ltd.	RSGE178	Ampere rating: 100-450A, Voltage rating: 1500Vdc Temperature: -40°C to +85°C	IEC 60269-7:2021 IEC 60269-1:2006+A1+A2	TÜV Rheinland R 50578436 0001
Main Busbar	Hangzhou Kaibenite Technology Co., LTD	XN1338-0076/PDU-E15-C250-301W/Coppers	Specification: 20mm*4mm Material: Copper	EN 62477-1:2012+A1:2017	Tested with apparatus
Switch-Disconnecter	Shanghai Liangxin Electrical Co., Ltd.	NDM3Z-250V	Rated voltage: 1500 V DC Rated current: 250A Temperature: -30°C to +70°C	EN 60947-2:2017/A1:2020	TÜV SÜD N8A 083574 0243 Rev.02
Main positive negative DC Relay	Sanyou Corporation Limited	SEF350-V1500MF24 2	Rated voltage: 1500 V DC Rated current: 350A Temperature: -40°C to +85°C	EN IEC 60947-4-1:2019	TÜV SÜD N8A 124740 0002 Rev.00
Precharge relay	Sanyou Corporation Limited	SEF40-V1500M24	Rated voltage: 1500 V DC Rated current: 350A Temperature: -40°C to +85°C	EN IEC 60947-4-1:2019	TÜV SÜD N8A 124740 0002 Rev.00
BCU in High voltage box(model: BCU-B30-201)					
BCU	HANGZHOU XIENENG TECHNOLOGY CO., LTD	BCU-B30-201	Software version: 13.81.5.8.15 Hardware version: V1.1	EN 62477-1:2012+A1:2017	Tested with apparatus
- PCB material	SHANGHAI GLOBAL ELECTRONIC MATERIAL LTD	GF11_T6	CTI: >600 Flame level: V-0 Thickness: 0.63-1.4mm	UL94 UL746	UL E224772 (2014-06-25)

- IC for MCU (U6)	ST	STM32F407 ZGT6	Working voltage: 1.8V to 3.6V Working temperature: -40°C to +85°C Flash memory: 192+4KB Memory: 1MB	EN 62477-1:2012+A1:2017	Tested with apparatus
- IC for AFE(U2)	NXP	MC33772	Working voltage: 6V to 30V Working temperature: -40°C to +125°C	EN 62477-1:2012+A1:2017	Tested with apparatus
- MOSFET for driving H&LSD (QHL1,QHL2)	FETek	FKS4113	Leakage source voltage (Vdss): 40V Continuous drain current (Id): 7.5A	EN 62477-1:2012+A1:2017	Tested with apparatus
- IC for communication isolator (UN2, UN4, UN8, UN11, UN12)	Suzhou Naxin Microelectronics Co., Ltd	NSi8221N1	Isolation voltage: 3.75kVrms Working voltage: 2.5V to 5.5V Working temperature: -40°C to +125°C	EN 62477-1:2012+A1:2017	Tested with apparatus
- Transformer (TR5)	SHENZHEN SINODRIVE ELECTRIC TECHNOLOGIES CO.,LTD	N12103S	Working voltage: 1500V Working temperature: -40°C to +125°C	UL62368-1	UL E523028 (2024-12-06)
- Optical coupler (UH1, UH2, UH3)	Xiamen Hualian Electronics Corp., Ltd	HSSR-61A0D-2	Isolation voltage: 5kVrms Working temperature: -40°C to +85 °C	UL1577	UL E178703 (2024-12-06)
- BCU shell	FORMOSA CHEMICALS & FIBRE CORP PLASTICS DIV	PC/ABS AC610G	CTI:0 Flame level: V-0 Thickness: 1.5-21.7mm	UL94 UL746A UL746B	UL E162823 (2025-02-27)
Power Box type ZJZP-LES-241L120 for Outdoor Energy Storage System LES-241L120, LES-241L80, LES-241L60					
Manufacturer: Golen Power Technology Co., Ltd.					
Enclosure of Power box	Golen energy technology co.,ltd	ZJZP-LES241L120	-35 °C -+75 °C 200A 380/400/415V	IEC 62477-1 EN 62477-1	Tested with apparatus
Power Supply (UPS)	Lianzheng Electronic (Shenzhen) Co Ltd	YEDU	1kVA/1kW 220V 0 °C ~ 50 °C	UL 1778, 5th Ed.	UL E321205
Moulded case circuit breaker	Shanghai Liangxin Electrical Co., Ltd.	NDM3-250MZ/3310	200A+CS1-A (Shunt DC 24V, hand operation length 300mm) -35 °C -+75 °C 200A 380/400/415V	EN 60947-2:2017+A1	TUV R 50519149

Connector	PHOENIX CONTACT GmbH & Co. KG	MPT1.5/S	500V 17.5A -60 °C ~+110 °C	UL 1059, Edition 5	UL-US- L60425- 61871103- 80013102- 1
Fuse (Low-voltage Fuse)	Mersen Zhejiang Co.,LTD.	RT18-32 (RO15)	Overall size: $\varnothing$ 10.3*38mm D*L Rated voltage: 380/500V Rated current: 0.5-32A Weight: 7.7g -5 °C ~+60 °C	EN 60269- 1:2007+A1+A2	TUV AN 50485014 001
Switch- disconnecter(Fuse- disconnecter)	Mersen Zhejiang Co., LTD.	RT18-32	1P/690V/32A -5 °C ~+40 °C	EN 60947- 3:2009+A1+A2	TUV R 50485009 0001
Switching Power Supply	Mersen Zhejiang Co., LTD.	LRS-200-24	Input voltage: 180- 264VAC Output voltage: 24VDC Rated current: 8.8A Rated power: 211.1W -25 °C ~+70 °C	UL62368-1	UL E183223

Pictures of the unit



Overview - Front view



Overview - Back view

Pictures of the unit



Overview - Front and PCS view (With / Remove terminal cover)



Overview - Back and side view

Pictures of the unit



Internal view – Open doors



Overview view – Auxiliary, Circuit Breaker

Pictures of the unit



EMS




LCD

Pictures of the unit



Overview – High Voltage Box



Overview – Liquid Cooling System

Pictures of the unit




Overview - Battery Pack



Bonding – Control Carbine

Pictures of the unit




PE terminal



Terminal View

Pictures of the unit




Internal view - Battery Pack



Internal and terminal view - Battery Pack

Pictures of the unit




Front view - Battery Pack sampling board



Back view - Battery Pack sampling board

Pictures of the unit




Front view-BCU




Back view-BCU

Pictures of the unit



Front view-BCU board



Back view-BCU board

Pictures of the unit



Overview – PCS terminal



Internal – PCS

Test Equipment list				
No	Test Equipment	Equipment model	Equipment No.	Calibration due date
1	Simulation of ac power supply	WPLA-330200KVA	BZ-DGD-L204	2025/09/09
2	Solar IV simulator	WLPA-150KW	BZ-DGD-L013	2025/07/31
3	Programmable AC Load	ACLT-38160H	BZ-DGD-L003	2025/09/09
4	Power analyser	PA6000	BZ-DGD-L059	2025/08/07
5	Temperature recorder	34970A	BZ-DGD-L332	2026/01/06
6	Hi-Pot & IR tester	19032	BZ-DGD-L066	2026/01/08
7	Pull and push	2P-1000	BZ-DGD-L080	2026/01/07
8	Thermostat	16m ³	BZ-DGD-L015	2025/05/10
9	Surge generator	HCWG 70	BZ-DGE-L036	2026/01/05
10	Noise meter	TES-1357	BZ-DGD-L029	2025/02/20
11	Power analyser	MS04054B	BZ-DGD-L119	2025/08/05
12	Touch current test network	/	BZ-DGD-L091	2025/07/31
13	Ground Resistance Tester	LK2678	BZ-DGD-L095	2025/07/31
14	Digital Caliper	DL91200	BZ-DGD-L240-1	2025/08/06

Statement

1. The laboratory guarantees the scientificity, accuracy and impartiality of the test, and is responsible for all the information in the report, except the information provided by the customer. The customer is responsible for the impact of the information provided on the validity of the results.
2. The report without China inspection body and laboratory Mandatory Approval (CMA) mark has no effect of proving to the society.
3. For the report with CNAS mark, the items marked with "☆" are not within the accredited scope.
4. This report is invalid if it is altered, without the signature of the testing and approval personnel, or without the "inspection and testing dedicated stamp" or test report stamp.
5. The test data and results are only valid for the tested samples provided by the customer.
6. This report shall not be partially reproduced without the written permission of the laboratory.
7. Any objection shall be raised to the laboratory within 30 days after receiving the report.

--- End of report---

CDF (Constructional Data Form) for Electrical Products


Applicant..... :	Yixing JS Solar Co., Ltd. No.501, Lvyuan Road, Yixing, China
Manufacturer :	Yixing JS Solar Co., Ltd. No.501, Lvyuan Road, Yixing, China
Factory..... :	Chuzhou Golen Power Co., Ltd. North Side Of Wen'an Road, Chahe Economic Development Zone, Lai'an County, Chuzhou City, Anhui Province, 239000, P.R. China
Product(s)..... :	Outdoor Energy Storage System
Standard(s)..... :	IEC 62477-1:2012+AMD1:2016, EN 62477-1:2012+A1:2017 EN 62477-1:2012+A12:2021
Model type(s)..... :	JSLES-241L120, JSLES-241L80, JSLES-241L60

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)


钮嘉星

(Applicant's legally authorized signature and stamp)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)




(Signature of authorized TÜV NORD CERT engineer)

Parameters:

Parameters:


Outdoor Energy Storage System			
Model or Type designation	JSLES-241L120	JSLES-241L80	JSLES-241L60
AC parameters:			
Rated Voltage [Va.c.]	230/400Vac, 3L/N/PE		
Rated Frequency [Hz]	50		
Rated Power [kW]	120	80	60
Max. Apparent Power [kVA]	132	88	66
Rated Current [Aa.c.]	173	115	87
Max. Current [Aa.c.]	191	127	95
Power Factor cosφ [λ]	-0.9 lagging ~0.9 leading		
Battery parameters:			
Battery capacity [Ah]	314		
Battery type	IFpP73/176/208/[[(48S)5S]]M/-30+55/95		
Rated energy [kWh]	241.152		
Rated voltage [Vd.c.]	768		
Voltage range [Vd.c.]	684~864		
Rated current [Ad.c.]	157		
Others:			
Protective Class	Class I		
Inverter Topology	Non-isolated		
Operation Temperature Range [°C]	-20 to 50 (>45 derating)		
Ingress Protection	PCS: IP20 Battery room: IP20 High Voltage box: IP54 Combiner box: IP54		
Weight [kg]	2400		
Dimension (W*D*H) [mm]	1000*1330*2350		
Overvoltage-Category	DC(BAT) II, AC(Main) III		

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)



(Applicant's legally authorized signature and stamp)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)



(Signature of authorized TÜV NORD CERT engineer)

Copy of marking plate:

JS SOLAR

Outdoor Energy Storage System

Model:JSLES-241L120 SN:JS20241122001

Battery Parameters

Battery Designation IFpP73/176/208/[[[(485)5S]]]
M/-30+55/95

Rated Energy 241.152kWh

Voltage Range 684~864Vdc

Rated Voltage 768Vdc

Rated Charge/Discharge Current 157A

AC Parameters

Rated Output Power 120kW

Max.Apparent Output Power 132kVA

Rated Voltage 3/N/PE , 230/400Vac

Rated Frequency 50Hz

Rated Current 173A

Max.Output Current 191A

Power Factor -0.9 lagging ~0.9 leading

Others

Ingress Protection IP54

Protective Class Class I

Operating Temp. Range -20℃~+50℃

Manufacture Date 2024.12.20

Yixing Js Solar Co.,Ltd.

JS SOLAR

Outdoor Energy Storage System

Model:JSLES-241L80 SN:JS20241122001

Battery Parameters

Battery Designation IFpP73/176/208/[[[(485)5S]]]
M/-30+55/95

Rated Energy 241.152kWh

Voltage Range 684~864Vdc

Rated Voltage 768Vdc

Rated Charge/Discharge Current 157A

AC Parameters

Rated Output Power 80kW

Max.Apparent Output Power 88kVA

Rated Voltage 3/N/PE , 230/400Vac

Rated Frequency 50Hz

Rated Current 115A

Max.Output Current 127A

Power Factor -0.9 lagging ~0.9 leading

Others

Ingress Protection IP54

Protective Class Class I

Operating Temp. Range -20℃~+50℃

Manufacture Date 2024.12.20

Yixing Js Solar Co.,Ltd.

JS SOLAR

Outdoor Energy Storage System

Model:JSLES-241L60 SN:JS20241122001

Battery Parameters

Battery Designation IFpP73/176/208/[[[(485)5S]]]
M/-30+55/95

Rated Energy 241.152kWh

Voltage Range 684~864Vdc

Rated Voltage 768Vdc

Rated Charge/Discharge Current 157A

AC Parameters

Rated Output Power 60kW

Max.Apparent Output Power 66kVA

Rated Voltage 3/N/PE , 230/400Vac

Rated Frequency 50Hz

Rated Current 87A

Max.Output Current 95A

Power Factor -0.9 lagging ~0.9 leading

Others

Ingress Protection IP54

Protective Class Class I

Operating Temp. Range -20℃~+50℃


Manufacture Date 2024.12.20

Yixing Js Solar Co.,Ltd.

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)


(Applicant's legally authorized signature and stamp)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)


(Signature of authorized TÜV NORD CERT engineer)

ESS-F-002 CDF

Page 3 of 12

Version 1.3


List of critical materials and components:

Object	Manufacturer	Type / model	Technical Data	Standard(s)	Remark
Key Components for Outdoor Energy Storage System JSLES-241L120, JSLES-241L80, JSLES-241L60 Manufacturer: Yixing JS Solar Co., Ltd.					
Enclosure of System	Nanjing Yuesheng Precision Machinery Co., Ltd	ZJJX-LES-241L120(V2.1)	Outdoor type 1000×1330×2350 Material: galvanized sheet Thickness: 2mm	IEC 62477-1 EN 62477-1	Tested with apparatus
Aerosol-Generating Extinguisher	Hubei Jiandun Fire Technology Co., Ltd	JAD300-U01	5m³ Ø76×192mm -40 °C - +54 °C	BS EN 15276-1:2019	BSI: KM 781135
Smoke Detector	Apollo Fire Detectors Limited Ltd	55000-316	100 mm diameter x 42 mm height (50 mm high with mounting base) -20 °C - + 60 °C	EN 54-7:2018	LPCB: 010q/11
Heat Detector	Hubei Jiandun Fire Technology Co., Ltd	55000-121	100 mm diameter x 42 mm height -20 °C - + 50°C	EN54-5:2000+A1:2002	LPCB: 010q /05
Emergency Stop Switch	IEDC CORP	HW1B-V411R	-25 °C to +60°C (no freezing) 24V 10A	UL 508, 18th Ed.	UL E68961
Air-cooled Chiller	ShenzhenEnvicool Technology Co., Ltd.	EMW50HFN C1A	refrigerating capacity@L35/W18:5K W heating capacity@Tu=10 °C:2KW Overall dimensions (H x W x D): 245×700×900mm Weight (without refrigerant):85KG -40°C ~+70°C	EN 62233:2008	TUV AM 50632900 0001
PCS	Golen Power Technology Co., Ltd.	LEG-135K-TL-P	DC:650-950V, AC:230/400V, 3/N/PE, 50Hz, Rated power: 135kW, IP 20, -30 °C ~55 °C	IEC 62477-1 EN 62477-1	TUV 44799254 06749-041

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)


Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)


(Applicant's legally authorized signature and stamp)



(Signature of authorized TÜV NORD CERT engineer)

Alarm Warning Devices	Hosiden Besson Limited	Banshee ExcelLite	Operating Voltage(V dc):9-30 Flash Current Consumption(mA):40(CHX),16(CHL) IP54 -15°C- +40 °C(CHX) -20 °C- +70 °C(CHL)	EN 54-3:2001 +A1:2002 +A2:2006	LPCB: 539c
Intelligent Dehumidifier	Andes (Zhejiang) Energy Technology Co LTD	ADSBD-500ML	-30 °C~+55 °C DC24V±10% 2.5A	UL 60335-1, 6th Ed	UL-US-2414393-0
Three-Phase Electric Meter	Acrel Co., Ltd.	DTSD1352-2CF	Reference voltage: 3*100V, 3*380V, 3*57.7/100V, 3*220/380V Power consumption: <10VA (single) Impedance: >2MΩ Accuracy class: Error ±0.2% Input current:3*1(6)A, 3*1(6)A(Transformer external), 3*10 (80) A, 3*10 (100) A (transformer external) Power consumption: <1VA(single-channel rated current) Accuracy class: Error ±0.2% active power, reactive power, apparent power, error ±0.5% grid frequency: 45 ~ 65Hz, error ±0.2% 5, power: active power (accuracy level 0.5S) Reactive power (accuracy level 2) -40 °C~99 °C	EN 61010-1:2010+A1:2019, EN IEC 61326-1:2021	UDEM: M.2022.20 6.C72763
Current Transformers	Acrel Co., Ltd.	AKH-0.66/K-ø24	300/5, 2000A/1A 50/60H z 0.66KV -30 °C -+70 °C	EN 61010-1:2019+A1:2019	Anbotek: AT78251S C205023

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)


(Applicant's legally authorized signature and stamp)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)


(Signature of authorized TÜV NORD CERT engineer)

Embedded Industry Computer	SIEMENS AG	KPT 700 Basic DP	230 mA DC +24 V -20-60 °C	UL508	UL E116536
Battery Pack	Golen power technology co., Ltd	LEH015303 14C19AV01	410.4~518.4Vd.c.,314 Ah, 144.69kWh,Class I, Charge/discharge Temperature: 5°C to 55°C/-15°C to 55°C	IEC 62477-1 EN 62477-1	TUV 44799254 06749-057
Battery Pack type LEH01530314C19AV01 for Battery System					
Manufacturer: Golen power technology co., Ltd					
Cell (48 cells provided)	Xiamen Hithium Energy Storage Technology Co., Ltd.	LFP7117320 7/314Ah	3.2V, 314Ah, 1004.8Wh	IEC 62619:2022	Certificate No.:JPTU V-152897 Test report NO.: JPTUV-152897
Enclosure of Battery Pack	Anhui FineMg Technology Co., Ltd.	48S battery box	Lower box: AlSi10MnMg Upper box cover: DC06 Liquid cooled plate: Al6061 Water connector: Al6061	EN 62477-1:2012+A1:2017	Tested with apparatus
NTC Resistor for cell (One Module contain 26 pcs)	MURATA	NCU18XH1 03F6SRB	R25 =10KΩ±1% B25/85=3434K±1% Temperature: -40°C to +125°C	UL1434	UL E137188 (2023-10-30)

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)



(Applicant's legally authorized signature and stamp)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)



(Signature of authorized TÜV NORD CERT engineer)

MSD	JONHON OPTRONIC TECHNOLOGY CO., LTD.	Plug: DLQ4B-T Socket: DLQ4B-Z-B	Rated voltage: 1500 V DC Rated current: 350A Temperature: -40°C to +125°C	UL 1977:2016 R8.19	TÜV Rheinland AK 50548173 0001
Insulation sheet	Chengdu Kanglongxin Plastics Co., Ltd	KLX FRPC- 1860B	Flammability: V-0 Temperature: +80°C	UL 746B	UL E315185 (2012-03- 08)
Sealing ring	Suzhou Hanming Electronic Materials Co., Ltd.	H050	working temperature: -55°C to +150°C V-0	UL94 IEC 60695-11- 10 UL746A UL746B	UL E537334 (2023-12- 28)
DC Connector Socket(B+B-)	JONHON OPTRONIC TECHNOLOGYCO , LTD	ICG- A08BKFJ28 RY-50 ICG- A08OGFJ28 RY-50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD Z2 113817 0002 Rev.03
DC Connector Plug(B+B-)	JONHON OPTRONIC TECHNOLOGYCO , LTD	ICG- A08OGTK0 S-50 ICG- A08BKT0R -50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD Z2 113817 0002 Rev.03
Main Busbar	Suzhou PNY Precision Technology CO., LTD.	T2	Rated current: DC 250A Thickness: 2mm	EN 62477- 1:2012+A1:20 17	Tested with apparatus
-Main Busbar Insulating sleeve	WUJIANG TUOYAN CO.,LTD	TY-HFT-600	Thickness:0.7mm, Flammability: V0 125°C	UL224	UL E479329 (2024-02- 01)
Internal wiring (signal)	ChangshuJHoSiN Communication Technology co.. Ltd.	UL2517	Temperature: 105°C RATED VOLTAGE: 300V	UL 758	UL E497461 (2018-04- 24)

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)

(Applicant's legally authorized signature and stamp)


Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)


(Signature of authorized TÜV NORD CERT engineer)

Internal wiring (Temperature)	JIANGYIN HAOCHENG ELECTRIC APPLIANCE WIRE & CABLE MFG CO LTD	UL10588	Temperature: +200°C RATED VOLTAGE: 600V	UL 758 CSA C22.2 No. 210	UL E227587 (2012-04-11)
Anti-Explosion Valve	Huizhou Voir Science&Technolo gy Co.,Ltd	VE-M582F-00-111	Pressure: 6±1.5Kpa Temperature: -40°C to +125°C	EN 62477-1:2012+A1:2017	Tested with apparatus
FUSE	Xi'an Sinofuse Electric Co., Ltd.	RS5C183	Rated Voltage: DC 250V Rated Current: DC 250 to 630A Temperature: -40°C to + 85°C Breaking Capacity: 50 kA	EN 60269-4:2009+A1+A2	TÜV Rheinland No.R5060 8448 0001
BMU Model BMU-B30-64-504					
BMU	HANGZHOU XIENENG TECHNOLOGY CO., LTD	Model: BMU-B30-64-504 (Hardware version:V1.4)	Monitoring the cells' temperature and voltage	EN 62477-1:2012+A1:2017	Tested with apparatus
-PCB material	SHANGHAI GLOBAL ELECTRONIC MATERIAL LTD	GF11_T6	CTI:>600 Flame level: V-0 Thickness: 0.63-1.4mm	UL94 UL746	UL E224772 (2014-06-25)
- IC for AFE (U4)	ADI	ADES1831C CSZ	Working voltage: 11V to 80V Working temperature: -40°C to +105°C	EN 62477-1:2012+A1:2017	Tested with apparatus
-Connector (JV1)	LOTES CO LTD	AAUS05AP5-016K02	Working temperature: -40°C to +85°C V-0	UL1977	UL E187055 (2024-12-06)
-Transformer (TJ1,TJ2)	Huizhou Youte Electronics Co., Ltd	UTA06C02	Working voltage: 1500V Working temperature: -40°C to +150°C	UL62368-1	UL E530055 (2024-12-06)
	Dongguan Jianxu Electronics Co., Ltd	TM0612SR	Working voltage: 1500V Working temperature: -40°C to +125°C	UL62368-1	UL E537506 (2024-12-06)

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)


(Applicant's legally authorized signature and stamp)


(Signature of authorized TÜV NORD CERT engineer)

-BMS shell	FORMOSA CHEMICALS & FIBRE CORP PLASTICS DIV	PC/ABS AC310(+)	CTI:0 Flame level: V-0 Thickness: 2.3mm	UL94 UL746A UL746B	UL E162823 (2025-02-27)
HV box type LBC-HL-2 for Battery System type 1) LEH-4608-L3, 2) LEH-6144-L4, 3) LEH-7680-L5 Manufacturer: Golen Power Technology Co., Ltd.					
Enclosure of HV box	Hangzhou Kaibenit e Technology Co., LTD	XN1338- 0076/PDU- E15-C250- 301W/Metal Plate	Material: SPCC Thickness: 2mm	EN 62477- 1:2012+A1:20 17	Tested with apparatus
DC Connector (socket P+P- B+B-)	JONHON OPTRONIC TECHNOLOGYCO , LTD	ICG- A08BKFJ28 RY-50 ICG- A08OGFJ28 SX-50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD No.Z2 113817 0002 Rev.03
DC Connector (plug P+P- B+B-)	JONHON OPTRONIC TECHNOLOGYCO , LTD	ICG- A08BKT0R -50 ICG- A08OGTK0 S-50	Rated Voltage: DC 1500V Rated Current: DC 250A Temperature: -40°C to +125°C	PPP 51090A:2018	TÜV SÜD No.Z2 113817 0002 Rev.03
Precharge resistor	Anhui Kebi Electronic Technology Co.,Ltd	RXLG- 200W-50R J	200W 50Ω Temperature: -55°C to +275°C	EN 60204- 1:2018	UDEM CE: E2021NB0 17JS-MD
AC-DC converter	ATAZ Guangzhou Science&Technolo gy Co.,Ltd.	AM200-B24	24V/8.8A Temperature: -40°C to +70°C	UL 62368-1	UL E2436674 (2025-01-03)
DC-DC converter	ATAZ Guangzhou Science&Technolo gy Co.,Ltd.	HV200- 15DB24	24V/8.333A Temperature: -40°C to +70°C	UL 1741	UL E541908 (2024-12-06)
Hall Sensor	LEM	DHAB S/124	Measuring range:±500A Temperature: -40°C to +125°C	UL 508	ULE18971 3 (2019-09-25)
Fan	TINGXIANG ELECTRIC (SHANGHAI) CO LTD	TX8025D24 B	24V 0.8A Temperature: -40°C to +70°C	UL 507	UL E526072 (2024-12-30)

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)



(Applicant's legally authorized signature and stamp)


Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)




(Signature of authorized TÜV NORD CERT engineer)

Fuse	Xi'an Sinofuse Electric Co., Ltd.	RSGE178	Ampere rating: 100-450A, Voltage rating: 1500Vdc Temperature: -40°C to +85°C	IEC 60269-7:2021 IEC 60269-1:2006+A1+A2	TÜV Rheinland R 50578436 0001
Main Busbar	Hangzhou Kaibenit e Technology Co., LTD	XN1338-0076/PDU-E15-C250-301W/Coppers	Specification: 20mm*4mm Material: Copper	EN 62477-1:2012+A1:2017	Tested with apparatus
Switch-Disconnecto	Shanghai Liangxin Electrical Co., Ltd.	NDM3Z-250V	Rated voltage: 1500 V DC Rated current: 250A Temperature: -30°C to +70°C	EN 60947-2:2017/A1:2020	TÜV SÜD N8A 083574 0243 Rev.02
Main positive negative DC Relay	Sanyou Corporation Limited	SEF350-V1500MF242	Rated voltage: 1500 V DC Rated current: 350A Temperature: -40°C to +85°C	EN IEC 60947-4-1:2019	TÜV SÜD N8A 124740 0002 Rev.00
Precharge relay	Sanyou Corporation Limited	SEF40-V1500M24	Rated voltage: 1500 V DC Rated current: 350A Temperature: -40°C to +85°C	EN IEC 60947-4-1:2019	TÜV SÜD N8A 124740 0002 Rev.00
BCU in High voltage box(model: BCU-B30-201)					
BCU	HANGZHOU XIENENG TECHNOLOGY CO., LTD	BCU-B30-201	Software version: 13.81.5.8.15 Hardware version: V1.1	EN 62477-1:2012+A1:2017	Tested with apparatus
- PCB material	SHANGHAI GLOBAL ELECTRONIC MATERIAL LTD	GF11_T6	CTI: >600 Flame level: V-0 Thickness: 0.63-1.4mm	UL94 UL746	UL E224772 (2014-06-25)
- IC for MCU (U6)	ST	STM32F407ZGT6	Working voltage: 1.8V to 3.6V Working temperature: -40°C to +85°C Flash memory: 192+4KB Memory: 1MB	EN 62477-1:2012+A1:2017	Tested with apparatus
- IC for AFE(U2)	NXP	MC33772	Working voltage: 6V to 30V Working temperature: -40°C to +125°C	EN 62477-1:2012+A1:2017	Tested with apparatus

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)


Applicant's legally authorized signature and stamp

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)


(Signature of authorized TÜV NORD CERT engineer)

- MOSFET for driving H&LSD (QHL1,QHL2)	FETek	FKS4113	Leakage source voltage (Vdss): 40V Continuous drain current (Id): 7.5A	EN 62477-1:2012+A1:2017	Tested with apparatus
- IC for communication isolator (UN2, UN4, UN8, UN11, UN12)	Suzhou Naxin Microelectronics Co., Ltd	NSi8221N1	Isolation voltage: 3.75kVrms Working voltage: 2.5V to 5.5V Working temperature: -40°C to +125°C	EN 62477-1:2012+A1:2017	Tested with apparatus
- Transformer (TR5)	SHENZHEN SINODRIVE ELECTRIC TECHNOLOGIES CO.,LTD	N12103S	Working voltage: 1500V Working temperature: -40°C to +125°C	UL62368-1	UL E523028 (2024-12-06)
- Optical coupler (UH1, UH2, UH3)	Xiamen Hualian Electronics Corp., Ltd	HSSR-61A0D-2	Isolation voltage: 5kVrms Working temperature: -40°C to +85 °C	UL1577	UL E178703 (2024-12-06)
- BCU shell	FORMOSA CHEMICALS & FIBRE CORP PLASTICS DIV	PC/ABS AC610G	CTI:0 Flame level: V-0 Thickness: 1.5-21.7mm	UL94 UL746A UL746B	UL E162823 (2025-02-27)
Power Box type ZJZP-LES-241L120 for Outdoor Energy Storage System LES-241L120, LES-241L80, LES-241L60					
Manufacturer: Golen Power Technology Co., Ltd.					
Enclosure of Power box	Golen energy technology co.,ltd	ZJZP-LES241L120	-35 °C -+75 °C 200A 380/400/415V	IEC 62477-1 EN 62477-1	Tested with apparatus
Power Supply (UPS)	Lianzheng Electronic (Shenzhen) Co Ltd	YEDU	1kVA/1kW 220V 0 °C ~ 50 °C	UL 1778, 5th Ed.	UL E321205
Moulded case circuit breaker	Shanghai Liangxin Electrical Co., Ltd.	NDM3-250MZ/3310	200A+CS1-A (Shunt DC 24V, hand operation length 300mm) -35 °C -+75 °C 200A 380/400/415V	EN 60947-2:2017+A1	TUV R 50519149
Connector	PHOENIX CONTACT GmbH & Co. KG	MPT1.5/S	500V 17.5A -60 °C -+110 °C	UL 1059, Edition 5	UL-US-L60425-61871103-80013102-1

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)



(Applicant's legally authorized signature and stamp)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)



(Signature of authorized TÜV NORD CERT engineer)

File No.: PVP07027/25E-001

Attached to Report No.: 492013971.001


Fuse (Low-voltage Fuse)	Mersen Zhejiang Co.,LTD.	RT18-32 (RO15)	Overall size: $\varnothing$ 10.3*38mm D*L Rated voltage: 380/500V Rated current: 0.5-32A Weight: 7.7g -5 °C~+60 °C	EN 60269- 1:2007+A1+A2	TUV AN 50485014 001
Switch- disconnecter(Fuse- disconnecter)	Mersen Zhejiang Co., LTD.	RT18-32	1P/690V/32A -5 °C~+40 °C	EN 60947- 3:2009+A1+A2	TUV R 50485009 0001
Switching Power Supply	Mersen Zhejiang Co., LTD.	LRS-200-24	Input voltage: 180- 264VAC Output voltage: 24VDC Rated current: 8.8A Rated power: 211.1W -25 °C~+70 °C	UL62368-1	UL E183223

----- End of CDF -----

Confirmation of the applicant
Jiangsu Yixing, 27/08/2025 (Place and date)


(Applicant's legally authorized signature and stamp)

Confirmation of TÜV NORD CERT
Shanghai, 27/08/2025 (Place and date)


(Signature of authorized TÜV NORD CERT engineer)